

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2022/976

Dated: 14/03/2022

**FIRE SAFETY CERTIFICATE**

Certified that **Sarvodaya Kanya Vidyalaya** located at F-Block, Budh Nagar, Inderpuri, New Delhi- 110012, comprised of ground plus three upper floors, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/SZ/2019/272 dated 04.02.2019. The school building was re-inspected by the officer concerned of Delhi Fire Service on 04.03.2022 in the presence of Sh. Vijay Pal Malik (Estate Manager) and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the school building is fit for occupancy class "Educational" with effect from 14/03/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the under mentioned conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below

Issued on 14/03/2022 at New Delhi by.



(Sunil Chaudhary)  
 Dy. Chief Fire Officer (SZ)  
 Delhi Fire Service

Copy to: -

1. The Principal, Sarvodaya Kanya Vidyalaya, F-Block, Budh Nagar, Inderpuri, New Delhi-110012.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

**Conditions for the Validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. Basement used only for storage purpose as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya, F-Block, Budh Nagar, Inderpuri, New Delhi- 110012
2. Type of Occupancy : Educational
3. Building Composition : Building comprised of ground plus three upper floors.
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/School/SZ/2019/272 dated 04.02.2019
6. Fire Safety directives letter No : N/A
7. Date of inspection : 04.03.2022
8. Name of the Inspecting Officers : P.V. Rathee, Asstt. Div. Officer (SRD.)
9. Name and designation of officers from the building side : Sh. Vijay Pal Malik (Estate Manager)
9. Year of Construction : 1984
10. Applicant's letter No. : Ref. No. 106 dated 25.02.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 04.02.2019	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02	02	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts or less & 0.75 mt	1.30 mts. each	MR being old case
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	Old case	2.35 mts	MR
	h. Door Size	Old case	Provide (0.95 mt)	MR being old case
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	Sealed	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	12 nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	02	Provided	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	N/A	100 mm	N/A
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	N/A	02 Nos.	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	02 Nos.	N/A
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
13	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	---	----	-----
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting/ Manual stopping</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>	----	-----	-----
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	450 LPM	450 LPM x 02 Nos.	MR
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	40 mts	40 mts each	MR
	<ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>	N/A	N/A	N/A
14	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	10000 lts	10000 lts	MR
15	<b>Exit Signage.</b>	Required	Provided	MR



16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked at random and found satisfactory at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/School/SZ/2019/272 dated 04.02.2019, renewal under Rule 37 of Delhi Fire Service Rules- 2010, is recommended.

DFA is put up for approval and signature please .

*[Handwritten Signature]* 7/3/22

Signature of Inspecting Officer  
(P.V. Rathee)  
Asstt. Divisional Officer (SRD)

D.O. (S/W)

*[Handwritten Signature]*

7/3/22

Dy CFO (SZ)

*[Handwritten Signature]*

*[Handwritten Signature]*

A NO (SRD)

FT Letter is put up for sign please

DY CFO (SZ)

*[Handwritten Signature]*

7/3/22

M.S. *[Handwritten Signature]*