

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SCHOOL/SZ/2022/ 120

Dated: 17/03/2022

FIRE SAFETY CERTIFICATE

Certified that the building India International Institute of Democracy and Election Management Located at Plot No – 01, Sector – 13, Dwarka, New Delhi running at G+ 04 UF in a building comprised of Basement(not in use) + G + 4 UFS was issued FSC vide Letter No: F6/DFS/MS/2018/SZ/2729 Dated 18/12/2018. The premises was re inspected by the officer concerned of this department on 05/03/2022 in the presence of Sh. BR. Modak GM (Engg.) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "Educational" Group B with effect from 17/03/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/03/2022 at New Delhi by.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

17/03/2022

Copy to:

1. The Principal Secretary, IIIDEM, ECI, Sec-13, Dwarka Delhi.
2. Sh. BR. Modak GM (Engg.), India International Institute of Democracy and Election Management Plot No – 01, Sector – 13, Dwarka, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N/19
INSPECTION REPORT

1. Name & address of the building: India International Institute of Democracy and Election Management Located at Plot No – 01, Sector – 13, Dwarka, New Delhi.
2. Type of Occupancy : Educational running at **Ground +04 UF in a building comprised of Basement(not in use) + G + 4 UFS**
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2018/SZ/2729 Dated 18/12/2018
(Issued for Ground + 4 upper floors)
5. Fire Safety directives L. No. : F6/DFS/MS/BP/2015/202 Dated 02/07/2015
6. Date of inspection : 05/03/2022
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. BR. Modak GM (Engg.)
9. Year of Construction : 2015-16
10. Applicant's letter No. : Email Dated-21/01/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement as N/10	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	10mtrs	MR
	• Gate width	4.5mtrs	Provided	MR(Old case)
	• Width of internal road	Required	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 No's	03 No's	MR
	• Basements	NA	Basement is closed	NA
	b. Width of staircases			
	• Upper floors	1.5mtr each	Provided	MR
	• Basements	NA	Basement is closed	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	03 No's	03 No's	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1.5 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	02 Hrs	Provided	MR
	• Water Curtain	Required in basement	Basement is closed	NA
	• Fire Dampers	NA	NA	NA

B

N/20

15
16

4.	Smoke managements System			
	• Basements	30 a/c per hour	Basement is closed	MR
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	45 nos.	45 Nos.	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02 no.	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke / Heat-	Provided	MR
	• Location of Main Panel	GF	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	100 mm	MR
	• Number of hydrants per floor	02 Nos.	Provided	MR
	• Hose Box	02 Nos.	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	06 Nos.	Provided	MR
	• Hose Box	06 Nos.	Provided	MR
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	2 X 2280 Lpm; 01 X 900 LPM		MR
	• Head of main pump	40 mtr	40 mtr	MR
	• Number of main pumps	03	03	MR
	• Jockey pump out put	180 LPM	Provided	MR
	• Jockey pump head	40 mtr	40 mtr	MR
	• Standby Pump out put	3180 LPM	Provided	MR
	• Standby Pump Head	50 mtr	50 mtr	MR
	• Auto Staring/Manual stopping	Required	Provided	MR
	• Pump House Access	Required	Provided	MR
	• Terrace level			
	• Discharge of pump	450 lpm	Provided	MR
	• Head of the pump	40Mtr	Provided	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	1,00,000 ltr	Provided	MR
	• Draw off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead Tank capacity	25,000Ltr	Provided	MR

N/21

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Manual gas flooding / linear heat sensing tube with CO2 cylinder found provided near HT / LT panel		Provided MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/2018/SZ/2729 Dated 18/12/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Udai Vir Singh
10/3/22

Signature of the Inspecting Officer
Name Udai Vir Singh
Designation ADO/DWK

Udai Vir Singh

Udai Vir Singh
11/3/22

Udai Vir Singh
12/4/22

Udai Vir Singh
11/3

Udai Vir Singh

Udai Vir Singh

Udai Vir Singh
11/3/22

Udai Vir Singh
15/3

ADO (Dwarka)

