

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2022/ 121

Dated: 17/03/2022

FIRE SAFETY CERTIFICATE

Certified that the Community hall Located at Sector – 2, Dwarka, New Delhi comprised of Basement+ Ground + 4 Upper Floors owned/ occupied by DDA have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the team of officers concerned of this department on 07/03/2022 in the presence of Mr. Vinod Kumar (EE DDA) and found that the said premises is fit for occupancy class 'D' "Assembly Building" (Community Hall) with effect from 17/03/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....17/03/2022.....at New Delhi by.

Yours faithfully,

  
(Anil Garg)  
Director,  
Delhi Fire Service.

Copy to:

1. The Executive Engineer (E)/ELD-5/DDA, Delhi Development Authority, Electrical Division-5, Central Nursery, Sector -5 Dwarka, New Delhi-110075.
2. The Chief Engineer (Dwarka) / DDA, Manglapuri, Delhi.
3. Mr. Vinod Kumar (EE DDA) Community hall Located at Sector – 2, Dwarka, New Delhi

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

Re inspection to see the compliance of shortcomings communicated vide letter dated 25/10/2021

**INSPECTION REPORT**

1. Name & address of the building: Community hall Located at Sector – 2, Dwarka, New Delhi.
2. Type of Occupancy : Assembly (B+ G + 4 Upper Floors)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2014/292 dated 24/10/2014
6. Date of inspection : 07/03/2022
7. Name of the Inspecting Officer : DO/SW & ADO/DWK
8. Name and designation of Officer  
from the building side : Mr. Vinod Kumar (EE DDA)

9. Year of Construction : 2015-2016

10. Applicant's letter No. : Email dated 22/02/2022

Area of the plot= 1988.58m <sup>2</sup> Covered Area =576.36 m <sup>2</sup> Height of the building= 18.9 M
--

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	13m Provided	MR
	• Gate width	5 m	6 m. Provided	MR
	• Width of internal road	6m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 Provided	MR
	• Basements	2	2 Provided	MR
	b. Width of staircases			
	• Upper floors	2 X2 m	Provided	MR
	• Basements	2X2 m	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	2	provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2 m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

*h*

*[Signature]*

4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	Required	Provided	MR
		NA	Natural ventilation provided	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	12nos. Water co2& CO2 ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First -Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	1	Provided	MR
		36 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Smoke	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm	Provided	MR
		1	Provided	MR
		Required	Provided	MR
12.	Yard Hydrants:			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	Required	Provided	MR
		Required	provided	MR
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	2280 lpm	Provided	MR
		40 m	Provided	MR
		1	Provided	MR
		180 lpm	Provided	MR
		40 m	Provided	MR
		2280 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		900 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

N/16

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	75000 litres	provided	MR
	➤ Draw off connection	Required	provided	MR
	➤ Fire service inlet	Required	provided	MR
	➤ Access to tank	Required	provided	MR
	• Overhead Tank capacity	10000 litres	provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	provided	MR
	➤ Fireman's Grounding Switch	Required	provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided at Ground level	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

*[Handwritten signature]*  
8/3/22

Sign of Inspecting Officer  
Name *Sb. Vedpal*  
Designation *DOSW*

*[Handwritten signature]*  
8/3/22

Sign of Inspecting Officer  
Name *Uday Vir Singh*  
Designation *ADO/DOSH*



*[Handwritten signature]*  
CFO (S2)

*[Handwritten signature]*  
9/3

*[Handwritten signature]*  
CFO

one of the sheet copyed N/9 was building plans, as sno 19 29. width of internal road as not been mentioned as we lost inspect it was 540 cm to 600 cm.  
*[Handwritten signature]*  
10/3

*[Handwritten signature]*  
Mx