

C-10

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2022/NDZ/ 297

Dated: 21 / 03 /2022

FIRE SAFETY CERTIFICATE

Certified that the Mother Heritage School located at C-II-105, Kh. No. 402/268, New Ashok Nagar, Delhi-110096 comprised of Ground + One Upper Floor only owned / Occupied by Mother Heritage School have been issued Fire Safety Certificate vide letter No. F.6/DFS/MS/School/2018/NDZ/1168 dated 22/05/2018. The premises was re-inspected by the officer concerned of this department on 15.03.2022 in the presence of Smt. Neelam Aggarwal and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Director of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 21 / 03 /2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 21/03/2022 at New Delhi by


21/03/22

(Dr. S.K. TOMAR)

DY. CHIEF FIRE OFFICER.

Copy to: -

1. The Manager, Mother Heritage School, C-II-105, Kh. No. 402/268, New Ashok Nagar, Delhi-110096.
2. The Director of Education, Udyog Sadan, Plot No.-419, FIE, Patparganj Industrial Area, Delhi-110092.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in.

INSPECTION REPORT

| | | | | |
|-------|---|---|------------------|-----------------------|
| 1. | Name & address of the building | Mother Heritage School, C-II-105, Kh. No. 402/268, New Ashok Nagar, Delhi-110096. | | |
| 2. | Type of Occupancy | Educational | | |
| 3. | Building Comprised of | G + 1 upper floor | | |
| 4. | Type of Case | Renewal | | |
| 5. | Details of previous NOC | F.6/DFS/MS/School/2018/NDZ/1168 dated 22/05/2018 | | |
| 6. | Fire Safety directives Letter No | DOE Cir. Dated 01/03/2011 | | |
| 7. | Date of Inspection | 15.03.2022 | | |
| 8. | Name of the Inspecting Officer | D.O. (East) | | |
| 9. | Name and Designation of Officer from the building side | Smt. Neelam Aggarwal | | |
| 10. | Year of Construction | 2001 | | |
| 11. | Applicant's letter received Email | apoorvea.594X@gov.in dated 14/03/2022 | | |
| S. No | Minimum standards on fire prevention and fire safety U/R 33 | DOE Cir. Requirements | Provided at site | Remarks MR/NMR |
| 1. | Access of building | | | |
| | • Road width | 6m | 6m | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | 1 | 1 | MR (earlier accepted) |
| | • Upper floors | NA | NA | NA |
| | • Basements | | | |
| | b. Width of staircases | 1.50 m | 1.50m | MR |
| | • Upper floors | NA | NA | NA |
| | • Basements | | | |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | 1 | 1 | MR |
| | e. Width Of Corridor | 1.5m | 1.5m | MR |
| | f. Door Size | 1m | 1.5m | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke managements System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 4 | 4 | MR |
| | • Types | ABC / CO ₂ | Provided | MR |
| | • ISI marking | ISI Marked | Provided | MR |
| 6. | First - Aid Hose Reels | | | |
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |



116

| | | | | |
|-----|--|----|----|----|
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detector | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | | | |
| 9. | Public Address System | | | |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down- comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main pump | NA | NA | NA |
| | ➤ Head of main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Staring/Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | | | |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power supply | NA | NA | NA |
| | ➤ Auto starting of pump | NA | NA | NA |
| 14. | Captive water Storage for fire fighting | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw of connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15. | Exit Signage | | | |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | | | |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |

| | | | | |
|-----|--|----|----|----|
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

Note:- General requirements for schools as per Director of Education circular dated 01/03/2011.


1. Escape route:- **Clear**
2. LPG cylinders in laboratories :- **Nil**
3. Electric wiring:- **Conduit Wiring MCB and ELCB.....**
Electric circuit:- **MCB Provided**
4. Electric meter board:- **Not under staircase**
5. Basement use as per BBL 1983 :- **N/A**
6. Emergency telephone no. board :- **Displayed**
7. Generator set :- **NA**

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2018/NDZ/1168 dated 22/05/2018, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

[Signature]
16/03/22

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation: D.O. (East)



Dy. C.F.O. (NDZ) P. Apark

[Signature]
16/3/22

Dy. C.F.O. Sir, As Approved, F.T. is added for
sign. please.

[Signature]
17/03/2022

Dy C.F.O. (NDZ)

[Signature]
21/3/22

mas