

C-13

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No.F6/DFS/MS/School/SZ/2022/307

Dated: 23/03/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Bal Vaishali Vinayaka School** located at **K-320, Jaitpur, Badarpur, New Delhi**, comprised of **basement + ground + 02 upper floors** was granted Fire Safety Certificate by this department vide letter no.- F6/DFS/MS/School/2019/SZ/190 dated 25.01.2019. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 07.03.2022 in the presence of Mrs. Anju Sharma, Principal and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. 3298 to 3398 dated 01.03.2011 issued by the Director of Education and the building (**Basement + Ground floor + 02 upper floors only**) is fit for occupancy of Group B "Educational Building" with effect from 23/03/2022 renewed for a period of three years, subject to conditions printed below.

Issued on 23/03/2022 at New Delhi by

  
(Sunil Chawdhary)

Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to:-**

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Bal Vaishali Vinayaka School located at K-320, Jaitpur, Badarpur, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT						
1	Name & address of the building	Bal Vaishali Vinayaka School located at K-320, Jaitpur, Badarpur, New Delhi.				
2	Building is comprised of	Basement + Ground + 2 upper floors				
3	Type of occupancy	Group B –Educational Building				
4	Type of case	Renewal				
5	Details of previous FSC	F6/DFS/MS/School/2019/SZ/190 dated 25.01.2019				
6	Fire safety direction letter no.	F6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011				
7	Date of inspection	07.03.2022				
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M.Road)				
9	Name of the designation of officer from the building side	Mrs. Anju Sharma, Principal				
10	Year of construction	2006				
11	Applicant's letter no.	Letter no. nil dated 17.02.2022				
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per DOE Circular dated 01.03.2011	Provided at site	Remarks MR/NMR		
1	<b>Access to Building:</b>					
	A	Road width	Accessible	Accessible	MR	
	B	Gate width	NA	NA	NA	
	C	Width of internal road	NA	NA	NA	
2	<b>Number, Width, Type and Arrangement of Exits:</b>					
	A	Number of staircases				
		a	Upper floor	02 nos.	2 nos.	MR
		b	Basement	02 nos.	02 nos.	MR
		B	Width of staircases			
		a	Upper floor	1 staircase of 1.5 mtrs or if main staircase width is < 1.5 mtrs an additional staircase of 0.75 mtrs width is required.	1.6 mtrs & 1.25mtrs	MR (Old Case)
		b	Basement	1 staircase of 1.5 mtrs or if main staircase width is < 1.5 mtrs an additional staircase of 0.75 mtrs width is required.	1.23 mtrs & 1.20 mtrs	MR (Old Case)
		C	Protection of exits			
		a	Fire check door	NA	NA	NA
		b	Pressurization	NA	NA	NA
		D	No. of continuous staircases to terrace	02 nos.	02 nos.	MR
		E	Width of corridor	1.5 mtrs.	1.5 mtrs.	MR
		F	Door size	1 mtrs.	1 mtrs.	MR
	3	<b>Compartmentation:</b>				
A		Fire check door	NA	NA	NA	
B		Sealing of electrical shafts	NA	NA	NA	
C		Fire rating of shaft door	NA	NA	NA	
D		Water curtain	NA	NA	NA	
E		Fire dampers	NA	NA	NA	
4	<b>Smoke Management System:</b>					
	A	Basement	Natural/ Mechanical	Exhaust fan	MR	
	B	Upper floor	NA	NA	NA	

<b>5.</b>	<b>Fire Extinguisher:</b>			
A	Total numbers	10 nos.	10 nos.	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	Required	Provided	MR
<b>6</b>	<b>First-Aid-Hose Reel:</b>			
A	Total numbers of each floor	01 nos.	01 nos.	MR
B	Length of hose reel hose	30 mtrs	30 mtrs	MR
C	Nozzle diameter	5 mm	5 mm	MR
<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>			
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	NA	NA
<b>8</b>	<b>MOEFA:</b>	Required	Provided	MR
<b>9</b>	<b>Public Address System:</b>	NA	NA	NA
<b>10</b>	<b>Automatic Sprinkler System: Area of basement is less than 200 m<sup>2</sup></b>			
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants:</b>			
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	01 no.	01 no.	MR
C	Hose box	01 no.	01 no.	MR
<b>12</b>	<b>Yard Hydrants:</b>			
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements:</b>			
A	<b>Ground level</b>			
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pumps	NA	NA	NA
d)	Jockey pump out put	NA	NA	NA
e)	Jockey pump head	NA	NA	NA
f)	Standby pump out put	NA	NA	NA
g)	Standby pump head	NA	NA	NA
h)	Auto starting /manual stopping	NA	NA	NA
i)	Pump house access	NA	NA	NA
B	<b>Terrace Level</b>			
a)	Discharge of pump	450LPM	450LPM	MR
b)	Head of the pump	40 mtrs	40 mtrs	MR
c)	Power supply	Required	Provided	MR
d)	Auto starting of pump	Required	Provided	MR

2/12

Bal Vaishali Vinayaka School located at K-320, Jaitpur, Badarpur, New Delhi

<b>14</b>	<b>Captive Water Storage for Fire Fighting:</b>				
A	Underground tank capacity	NA	NA	NA	
B	Draw-off connection	NA	NA	NA	
C	Fire service inlet	NA	NA	NA	
D	Access to tank	NA	NA	NA	
E	Overhead tank capacity	10,000 ltrs	10,000 ltrs	MR	
<b>15</b>	<b>Exit Signage:</b>		Required	Provided	MR
<b>16</b>	<b>Provision of Lifts:</b>				
A	Pressurization of lift shaft	NA	NA	NA	
B	Pressurization of lift lobby	NA	NA	NA	
C	Communication in lift car	NA	NA	NA	
D	Firemen's grounding switch	NA	NA	NA	
E	Lift signage	NA	NA	NA	
<b>17</b>	<b>Standby Power Supply:</b>		NA	NA	NA
<b>18</b>	<b>Refuge Area:</b>				
A	Total area	NA	NA	NA	
B	Location	NA	NA	NA	
<b>19</b>	<b>Fire Control Room:</b>				
A	Detector system panel	NA	NA	NA	
B	Flow switch panel	NA	NA	NA	
C	PA system panel	NA	NA	NA	
D	Battery backup	NA	NA	NA	
E	Building floor plans	NA	NA	NA	
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>		NA	NA	NA


**Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).**

However, Circular no. F6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 was issued by Directorate of Education for all existing schools hence making the circular dated 17.01.2005 null & void for existing schools.

Therefore this inspection has been carried out on the basis of DOE Circular no. F6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011.

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education Circular no. 3298 to 3398 dated 01.03.2011, the FSC issued vide letter no. F6/DFS/MS/School/2019/SZ/190 dated 25.01.2019 is recommended to be renewed.

  
 Signature of the Inspecting Officer  
 Name Rajesh Kumar Shukla  
 Designation ADO (M. Road)

DO (SD)

Defol (2)

Riv  
15/03/22



A DO/MR