

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No.F6/DFS/MS/School/SZ/2022/ 302

Dated: 23/03/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Modern Green Valley Public School** located at **L-1A, 33/17/1, Sangam Vihar, New Delhi**, comprised of **ground + 02 upper floors** was granted Fire Safety Certificate by this department vide letter no.- F6/DFS/MS/School/2019/SZ/354 dated 08.02.2019. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 14.03.2022 in the presence of Mrs. Sangeeta Rani, Principal and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises (**Ground + 2 upper floors**) is fit for occupancy of Group B "Educational Building" with effect from 23/03/2022 for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 23/03/2022 at New Delhi by



(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

etc BL  
16/3

**Copy to:-**

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Modern Green Valley Public School located at L-1A, 33/17/1, Sangam Vihar, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures. management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

10/19

INSPECTION REPORT					
1	Name & address of the building	Modern Green Valley Public School located at L-1A, 33/17/1, Sangam Vihar, New Delhi.			
2	Building is comprised of	Ground + 02 upper floor			
3	Type of occupancy	Educational			
4	Type of case	Renewal case			
5	Details of previous FSC	F6/DFS/MS/School/2019/SZ/354 dated 08.02.2019			
6	Fire safety direction letter no.	DFS Act 2007 & Rule, 2010			
7	Date of inspection	14.03.2022			
8	Name of the inspecting officers	Rajesh Kumar Shukla ADO (M.Road)			
9	Name of the designation of officer From the building side	Mrs. Sangeeta Rani, Principal			
10	Year of construction	2009			
11	Applicant's letter no.	Email dated 09.02.2022			
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR	
1	<b>Access to Building:</b>				
	Road width	6 mtrs.	6 mtrs.	MR	
	Gate width	NA	NA	NA	
	Width of internal road	NA	NA	NA	
2	<b>Number, Width, Type and Arrangement of Exits:</b>				
	<b>A</b>	Number of staircases			
	a	Upper floor	1 nos.	02 nos.	MR
	b	Basement	NA	NA	NA
	<b>B</b>	Width of staircases			
	a	Upper floor	1 staircase of 1.5 mtrs or if main staircase width is < 1.5 mtrs an additional staircase of 0.75 mtrs width is required.	1.35 mtrs to 1.5 mtrs & 0.90 mtrs (Iron)	MR
	b	Basement	NA	NA	NA
	<b>C</b>	Protection of exits			
	a	Fire check door	NA	NA	NA
	b	Pressurization	NA	NA	NA
	<b>D</b>	No. of continuous staircases to terrace	01 nos.	01 nos.	MR
	<b>E</b>	Width of corridor	1.5 mtrs.	1.5 mtrs.	MR
	<b>F</b>	Door size	1 mtrs.	1 mtrs.	MR
3	<b>Compartmentation:</b>				
	<b>A</b>	Fire check door	NA	NA	NA
	<b>B</b>	Sealing of electrical shafts	NA	NA	NA
	<b>C</b>	Fire rating of shaft door	NA	NA	NA
	<b>D</b>	Water curtain	NA	NA	NA
	<b>E</b>	Fire dampers	NA	NA	NA
4	<b>Smoke Management System:</b>				
	<b>A</b>	Basement	NA	NA	NA
	<b>B</b>	Upper floor	NA	NA	NA

De

20/20

<b>5. Fire Extinguisher:</b>				
A	Total numbers	06 nos.	06 nos.	<b>MR</b>
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	<b>MR</b>
C	ISI marking	Required	Required	<b>MR</b>
<b>6. First-aid-Hose Reel:</b>				
A	Total numbers of each floor	01 nos.	01 nos.	<b>MR</b>
B	Length of hose reel hose	30 mtrs.	30 mtrs.	<b>MR</b>
C	Nozzle diameter	5 mm	5 mm	<b>MR</b>
<b>7. Automatic Fire Detection and Alarming System:</b>				
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	NA	NA
<b>8</b>	<b>MOEFA:</b>	NA	NA	NA
<b>9</b>	<b>Public Address System:</b>	NA	NA	NA
<b>10. Automatic Sprinkler System:</b>				
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
<b>11. Internal Hydrants:</b>				
A	Size of riser/down-comer	NA	100 mm	NA
B	Number of hydrants per floor	NA	01 no.	NA
C	Hose box	NA	01 no.	NA
<b>12. Yard Hydrants:</b>				
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
<b>13. Pumping Arrangements:</b>				
<b>A. Ground level</b>				
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pumps	NA	NA	NA
d)	Jockey pump out put	NA	NA	NA
e)	Jockey pump head	NA	NA	NA
f)	Standby pump out put	NA	NA	NA
g)	Standby pump head	NA	NA	NA
h)	Auto starting /manual stopping	NA	NA	NA
i)	Pump house access	NA	NA	NA
<b>B. Terrace Level</b>				
a)	Discharge of pump	450 LPM	450 LPM	<b>MR</b>
b)	Head of the pump	40 mtrs.	40 mtrs.	<b>MR</b>
c)	Power supply	Required	Provided	<b>MR</b>
d)	Auto starting of pump	Required	Provided	<b>MR</b>





<b>14</b>	<b>Captive Water Storage for Fire Fighting:</b>				
	<b>A</b>	Underground tank capacity	10,000 Ltrs	10,000 Ltrs	<b>MR</b>
	<b>B</b>	Draw-off connection	NA	NA	NA
	<b>C</b>	Fire service inlet	NA	NA	NA
	<b>D</b>	Access to tank	NA	NA	NA
	<b>E</b>	Overhead tank capacity	NA	NA	NA
<b>15</b>	<b>Exit Signage:</b>		Required	Provided	<b>MR</b>
<b>16</b>	<b>Provision of Lifts:</b>				
	<b>A</b>	Pressurization of lift shaft	NA	NA	NA
	<b>B</b>	Pressurization of lift lobby	NA	NA	NA
	<b>C</b>	Communication in lift car	NA	NA	NA
	<b>D</b>	Firemen's grounding switch	NA	NA	NA
	<b>E</b>	Lift signage	NA	NA	NA
<b>17</b>	<b>Standby Power Supply:</b>		NA	NA	NA
<b>18</b>	<b>Refuge Area:</b>				
	<b>A</b>	Total area	NA	NA	NA
	<b>B</b>	Location	NA	NA	NA
<b>19</b>	<b>Fire Control Room:</b>				
	<b>A</b>	Detector system panel	NA	NA	NA
	<b>B</b>	Flow switch panel	NA	NA	NA
	<b>C</b>	Pa system panel	NA	NA	NA
	<b>D</b>	Battery backup	NA	NA	NA
	<b>E</b>	Building floor plans	NA	NA	NA
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>		NA		NA

**Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).**

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the NOC issued vide letter no. F6/DFS/MS/School/2019/SZ/354 dated 08.02.2019 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

*Rk*  
14/3/22

Signature of the Inspecting Officer  
Name Rajesh Kumar Shukla  
Designation ADO (M. Road)

~~DO (SD)~~

*Rk*  
15/03/22

*DeFO/SZ*

*F.f.*

*A.M.O./FCR/M.Rd*