

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/School/WZ/2022/ 293

Dated: 17/03/2022

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Vidyalaya Located at FU-Block, Pitampura, Delhi-110034, comprised of Ground + 03 Upper Floors only was issued Fire Safety Certificate by this department Vide Letter No F6/DFS/MS/WZ/2019/780 dated 09.04.2019. The said premises was re-inspected by the officer concerned of this department on 22.02.2022 in the presence of Sh. Sandeep Kumar (Estate Officer) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 17/03/2022 for a period of three years, subject to compliance of the conditions mentioned, printed overleaf.

Issued on ...17/03/2022 at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Sarvodaya Vidyalaya Located at FU-Block, Pitampura, Delhi-110034.

Following fire safety directives must be adhered to :-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

2/13
INSPECTION REPORT

1. Name & address of the building: **Sarvodaya Vidyalaya**, Located at **FU Block, Pitampura, Delhi -110034.**
2. Type of Occupancy: Educational (G + 03 Upper Floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2019/780 dated 09.04.2019
5. Fire Safety directives Letter No.: Cir. No. 3298-3398 dated 01.03.2011
6. Date of inspection : 22.02.2022
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Sandeep Kumar, Estate Manager
9. Year of Construction : 1988
10. Applicant's letter No. : SV/FU/PP/22/1216 dated 03.02.2022

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement /letter dated 09.04.2019	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Required	09 m	MR
	• Gate width	Required	05 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03	04	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	3 X 1.5 m	3 X 153 cm & 1 X 48 cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	Provided	MR
	e. Width Of Corridor	1.5mtr	203 cm	MR
	f. Door Size	1mtr	108 cm	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	20 nos.	48 Nos.	MR
	• Types	ABC &	Provided	MR
	• IS marking	CO ₂ ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor		03	Provided MR

2/1/14

	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	30m 5mm	Provided Provided	MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 450 lpm 40Mtr Required Required	NA NA NA NA NA NA NA NA NA NA NA 2 X 450 lpm Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 10,000Ltr	NA NA NA NA Provided	NA NA NA NA MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	NA NA	NA NA	NA NA
19.	Fire control room			
	<ul style="list-style-type: none"> Detector system panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA


[Handwritten signature]

M/S


20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/WZ/2019/780 dated 09.04.2019 is recommended under rules 37 of the Delhi Fire Service Rules 2010 under the DFS Act 2007.



 24/2/22.
 Aman Kumar Lathar
 ADO (JWP)

~~DO (W)~~


24/02/2022


D.O. (WEST) 2/2/22
DATED.. 23/2/2022


~~DO (W2)~~


2/2/2022

~~ADO (JWP)~~
F.F. letter is put-up for signature 1st.

~~DO (W2)~~


16/2/2022


10/2/22
A.M.O (JWP)

next step