

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS; DELHI FIRE SERVICE, CONNAUGHT PLACE**

No. F6/DFS/MS/GH/2022/WZ/ <sup>CHG</sup> 129

Dated: 25/03/2022

**FIRE SAFETY CERTIFICATE**

Certified that the CNG Station at Khasra No. 78/12/2/78/18, Village Ghevra, Tehsil Kanjhawala, Delhi-110043 Comprised of Ground Floor only (02 Nos. dispenser, 01 Nos. Compressor & 01 Nos. Cascade at Ground floor) owned/occupied by M/s. Indraprastha Gas Limited, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 12.03.2022 in the presence of Sh. Rohit Mahahjan and that the building/Premises is fit for occupancy "Hazardous Building" Group - J (CNG Pump) as above with effect from 25/03/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 below.

Issued on 25/03/2022 at New Delhi by

  
(Anil Garg)  
Director

Copy to:-

1. Sh. Pulkit Bhardwaj Chief Manager (CNG PROJECTS), IGL Bawan, Plot no. 4, Community Centre, Sector-9, R.K. Puram, New Delhi-110022.

**Conditions for the validity of Fire Safety Certificate:-**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of authorized construction or alteration (Clause of 1.4.3 of UBBL-2016), if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

1	Name & Address of the Building	CNG Station at Khasra No. 78/12/2/78/18, Village Ghevra, Tehsil Kanjhawala, Delhi-110043		
2	Type of Occupancy	Hazardous "Group- J"		
3	Type of Case	New (comprised of ground floor only & & having 01 no. Compressor & 02 nos. Dispenser)		
4	Details of Previous NOC	Nil		
5	Fire Safety Directives Letter No	F6/DFS/MS/CNG/2019/5808 dated 26.09.2019		
6	Date of Inspection	12.03.2022		
7	Name of the Inspecting Officers	Aman Kumar Lathar, ADO (JWP)		
8	Name & Designation of Officers from the building side	Sh. Surender Kumar (Manager)		
9	Year of construction	2020-21		
10	Applicant letter No.	IGL/CNG/NOC/2412221 dated 24.12.2021		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Requirements as per letter dt. 26.09.2019</b>	<b>Provided at Site</b>	<b>Remarks NR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>10.5 m</li> <li>-N/A-</li> <li>-N/A-</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>Direct accessible from road</li> <li>-N/A-</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>-N/A-</li> <li>-N/A-</li> </ul>
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	<ul style="list-style-type: none"> <li>➤ Upper floors.</li> <li>➤ Basement floor.</li> </ul>	<ul style="list-style-type: none"> <li>-N/A-</li> <li>-N/A-</li> </ul>	<ul style="list-style-type: none"> <li>-N/A-</li> <li>-N/A-</li> </ul>	<ul style="list-style-type: none"> <li>-N/A-</li> <li>-N/A-</li> </ul>
	<b>b) Width of Staircase</b>			
	<ul style="list-style-type: none"> <li>➤ Upper floors</li> <li>➤ Basement floor</li> </ul>	<ul style="list-style-type: none"> <li>-N/A-</li> <li>-N/A-</li> </ul>	<ul style="list-style-type: none"> <li>-N/A-</li> <li>-N/A-</li> </ul>	<ul style="list-style-type: none"> <li>-N/A-</li> <li>-N/A-</li> </ul>
	<b>Protection of exits</b>			
	<ul style="list-style-type: none"> <li>➤ Fire check door</li> <li>➤ Pressurization</li> </ul>	<ul style="list-style-type: none"> <li>-N/A-</li> <li>-N/A-</li> </ul>	<ul style="list-style-type: none"> <li>-N/A-</li> <li>-N/A-</li> </ul>	<ul style="list-style-type: none"> <li>-N/A-</li> <li>-N/A-</li> </ul>
	<b>c) No. of continuous staircase to terrace</b>	-N/A-	-N/A-	-N/A-
	<b>d) Width of corridor</b>	-N/A-	-N/A-	-N/A-
	<b>e) Door size</b>	-N/A-	-N/A-	-N/A-
<b>3</b>	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door.</li> <li>• Sealing of electrical shafts.</li> <li>• Fire rating of shaft door.</li> <li>• Water curtain</li> <li>• Fire dampers.</li> </ul>	<ul style="list-style-type: none"> <li>-N/A-</li> <li>-N/A-</li> <li>-N/A-</li> <li>-N/A-</li> <li>-N/A-</li> </ul>	<ul style="list-style-type: none"> <li>-N/A-</li> <li>-N/A-</li> <li>-N/A-</li> <li>-N/A-</li> <li>-N/A-</li> </ul>	<ul style="list-style-type: none"> <li>-N/A-</li> <li>-N/A-</li> <li>-N/A-</li> <li>-N/A-</li> <li>-N/A-</li> </ul>
<b>4.</b>	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> </ul>	<ul style="list-style-type: none"> <li>-N/A-</li> <li>-N/A-</li> </ul>	<ul style="list-style-type: none"> <li>-N/A-</li> <li>-N/A-</li> </ul>	<ul style="list-style-type: none"> <li>-N/A-</li> <li>-N/A-</li> </ul>
<b>5.</b>	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI Marking</li> </ul>	<ul style="list-style-type: none"> <li>07</li> <li>Required</li> <li>ISI marked</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>DCP 9kg- 04, wheel mounted 75 kg- 01, CO<sub>2</sub> 4.5 kg- 02, Water mist cum Foam trolley- 01</li> <li>Provided</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>MR</li> </ul>
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	-N/A-	-N/A-	-N/A-

	<ul style="list-style-type: none"> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>	-N/A-	-N/A-	-N/A-
7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Gas and flame detectors in compressor packages area, hand held explosive meter</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	Required	Provided	MR
		Required	At GF	MR
		-N/A-	-N/A-	-N/A-
		Required	Provided	MR
		Required	At Station	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	-N/A-	-N/A-	-N/A-
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement.</li> <li>Upper floors</li> <li>Sprinkler above false ceiling</li> </ul>	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser / Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>			
	Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	<b>Terrace Level</b>			
	➤ Discharge of pump.	-N/A-	-N/A-	-N/A-
	➤ Head of pump.	-N/A-	-N/A-	-N/A-
	➤ Power supply.	-N/A-	-N/A-	-N/A-
	➤ Auto starting of pump.	-N/A-	-N/A-	-N/A-
14.	<b>Captive water storage for firefighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> <li>➤ Draw-off connection.</li> <li>➤ Fire Service Inlet.</li> <li>➤ Access to tank.</li> <li>Overhead tank capacity.</li> </ul>	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
15.	<b>No Smoking/Flammable Gas Signage</b>	Required	Provided in Hindi & English	MR



<b>16.</b>	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	-N/A-	-N/A-	-N/A-
	• Pressurization of lift lobby.	-N/A-	-N/A-	-N/A-
	• Communication in lift car.	-N/A-	-N/A-	-N/A-
	• Fireman's switch.	-N/A-	-N/A-	-N/A-
	• Lift signage.	-N/A-	-N/A-	-N/A-
<b>17</b>	<b>Standby Power Supply</b>	-N/A-	Provided (DG Set)	-N/A-
<b>18.</b>	<b>Refuge Area</b>			
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-
<b>19.</b>	<b>Fire Control Room.</b>			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	N/A-	N/A-	N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
<b>20.</b>	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	Fire Buckets filled with sand, electrical wiring, in metal conduit, CO <sub>2</sub> flooding system in compressor package	Provided	MR


The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards of fire prevention and fire safety requirements as per fire safety guidelines issued vide letter no. F6/DFS/MS/CNG/2019/5808 dated 26.09.2019, it is recommended to issue Fire Safety Certificate.

Note:


1. Advance fire water mist com foam trolley is provided and found functional.
2. Two hand held explosive meter in working conditions.

Accordingly DFA is put up for approval and signature please.

  
 Aman Kumar Lathar  
 ADO (JWP)

D.O (West)

D.O. (WEST) 258  
 DATED. 22/03/22


  
 22/3/2022

~~D.O (W2)~~

  
 24/3/22

 On/Leave

~~Director (W2) 24/03/22~~

  
 P.O.