

E36

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2022/SZ/256

Dated: 10/03/2022

FIRE SAFETY CERTIFICATE

Certified that the **Navyug Convent School**, Sainik Enclave Part-II, Near C.R.P.F. Camp, Jharoda Kalan, New Delhi-110072, comprised of ground floor plus three upper floors, owned/occupied by Navyug Convent School was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/School/2019/SZ/1104 dated 22/05/2019. The School building was re-inspected by the officer concerned of this department on 22/02/2022 in the presence of Smt. Rajesh Yadav (Principal) and found that School building have deemed complied the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 10/03/2022 at New Delhi.


(SUNIL CHAUDHARY)
Dy. CHIEF FIRE OFFICER

Copy to:-

1. The Principal, Navyug Convent School, Sainik Enclave Part-II, Near C.R.P.F. Camp, Jharoda Kalan, New Delhi-110072
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/17

INSPECTION REPORT

1. Name & address of the building : Navyug Convent School, Sainik Enclave Part-II, Near C.R.P.F. Camp, Jharoda Kalan, New Delhi-110072.
 2. Building comprised of : Ground plus three upper floors.
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC : F.6/DFS/MS/School/2019/SZ/1104 dated 22/05/2019
 6. Fire Safety directives letter No : N/A
 7. Date of inspection : 22/02/2022
 8. Name of Inspecting Officer : A.D.O. R.K.Yadav
 9. Name and designation of officers
 From the building side : Smt. Rajesh Yadav (Principal)
 10. Year of Construction : 2014-15
 11. Applicant's letter No. : Form "J"(NCS/FIRE'CERT/1477) dated 12/02/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ Dt. of edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible (06 m) 4.5 m N/A	Provided Provided N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 No N/A	03 No's N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 m N/A	2x1.50 m (GF to TF) & 1.30 m (GF to SF) N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.5 m	2 m to 3.3 m	MR
	f. Class room Door Size	1.0 m	.90 & 1.03 m (few rooms have single doors)	M/R , being old case (Students less than 45 in each class)
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	Required	Natural ventilation	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	14 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R

N/D

16.	Provision of Lifts.	(No Lift)		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2019/SZ/1104 dated 22/05/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
24/2/2022

Signature of Inspecting Officer

Name:- R.K. Yadav

Designation:- Asstt. Divisional Officer

D.O. (South West)

dh
25/2/2022 F.F.

Dyefo (SZ)

dh

A DO / RD