

C/17

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2022/School/313

Dated: 25/03/2022

**FIRE SAFETY CERTIFICATE**

Certified that the Sevti Devi Memorial Sr. Sec. Vidya Mandir, located at Main Palam Dabri Road, Mahavir Enclave, Opp. Dasrathpuri Metro Station, Dwarka, New Delhi – 110045 comprised of small basement, Ground + One Upper Floor, was issued Fire Safety Certificate vide this department letter No. F.6/DFS/MS/School/2018/SZ/1418 Dated 18/06/2018. The premises was re inspected by the officer concerned of this department on 16/03/2022 in the presence of Ms. Tushita vats (Principal) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance DOE Circular 262-362 Dated 17/01/2005 and that the building is fit for occupancy class B “Educational building” with effect from 25/03/2022 for a period of three years. Subject to condition given below.

Issued on 25/03/2022 at New Delhi by.



(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service.

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054
2. Ms. Tushita vats (Principal) Sevti Devi Memorial Sr. Sec. Vidya Mandir, located at Main Palam Dabri Road, Mahavir Enclave, Opp. Dasrathpuri Metro Station, Dwarka, New Delhi – 110045

**Following fire safety directives must be adhered to:-**

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

AD 01/2  
24/3/22

N/6

**INSPECTION REPORT**

1. Name & address of the building: Sevti Devi Memorial Sr. Sec. Vidya Mandir, Main Palam Dabri Road, Mahavir Enclave, Opp. Dasrathpuri Metro Station, Dwarka, New Delhi – 110045.
2. Type of Occupancy : Educational (Small Basement, Ground + 01 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2018/SZ/1418 Dated 18/06/2018
5. Fire Safety directives Letter No. : . Circular. No 262-362 Dated 17/01/2005
6. Date of inspection : 16/02/2022
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer  
from the building side : Ms. Tushita vats (Principal)
9. Year of Construction : 2009
10. Applicant's letter No. : F-1-2/SDMSSVM/F/2022 Dated 28/02/2022

No. of Students=188
No. of class rooms=27
Plot area=2528.36 Sq.mtr
Covered area=1418 sq.mtr

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/3	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	Provided	MR
	• Gate width	4.5mtrs	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 No's	02 No's	MR
	• Basements	02 No's	02 No's	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr	1.66 m & 1.18 m	MR (Old case)
	• Basements	1.5 mtr	1.06 m & 0.54 m	MR (Old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5 m	Provided	MR (Old case)
	f. Door Size	1 mtr	0.9 m	MR (Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	• Basements	30 a/c per hour	Exhaust fan provided	MR
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	01 ABC for every 300 sq.mtr	10 Nos.	MR
	• Types	ISI marked	ABC	MR
	• IS marking		Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01 each floor	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	Provided at ground floor	NA
	• Hose Box	NA	Provided at ground floor	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	220 LPM	220 LPM	MR
	➤ Head of the pump	40 m	40 m	MR
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2500 ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/2018/SZ/1418 Dated 18/06/2018 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
 Name *Uday Kir Singh*  
 Designation *AO/DWR*

*(Signature)* *MS 23/5/22*  
*(Signature)*  
*(Signature)*  
*(Signature)*