

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

C/26


No: F6/DFS/MS/School/MN/2022 /311

Dated: 25/03/2022

FIRE SAFETY CERTIFICATE

Certified that the building of **South Delhi Municipal Corporation Primary School, Located at Chand Nagar, D- Block, JJ Colony, Khyala, New Delhi – 110015.** Owned/Occupied by **Delhi Municipal Corporation Primary School** comprised of Ground + 1 upper Floor (**Except G + 02 Upper Floor**) only was issued FSC vide letter No. F6/DFS/MS/WZ/2019/909 dated 29/04/2019. The premises was re-inspected by the officer concerned by this department on 11/03/2022 in the presence of Smt. Rajini (Incharge) of school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education Govt of NCT of Delhi, and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B – 1 with effect from 25/03/2022 for a period of three years subject to the compliance of the condition mentioned below:-

Issued on 25/03/2022 at New Delhi.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer,
Delhi Fire Service

Copy to:

1. The Vice - Principal, South Delhi Municipal Corporation Primary School, Located at Chand Nagar, D- Block, JJ Colony, Khyala, New Delhi – 110015.
2. Director of Education, Old Sectt. Delhi-110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

01/2/24
23/3/2022

INSPECTION REPORT

1. Name & address of the building : South Delhi Municipal Corporation Primary School, Located at Chand Nagar, D – Block, JJ Colony, Khyala, New Delhi – 110018.
2. Type of Occupancy : Educational (Ground + 1 Upper Floor) (Except G + 02 upper floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2019/909 dated 29/04/2019
5. Fire Safety directives letter No : DOE 3298-3398 dated 01/03/2011
6. Date of inspection : 11/03/2022
7. Name of the Inspecting Officers : Sarabjeet Singh (ADO/MN)
8. Name and designation of officers from the building side : Smt. Rajini (Incharge)
9. Year of Construction : 2018 (As per prev. Insp. report dtd 23/07/2019)
10. Applicant's letter No. : Letter Dated 17/02/2022

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | BBL /NBC Requirement(As per. Prev. Insp. Report dtd- 09/05/2018 | Provided at site | Remarks MR/NMR |
|--------|---|---|------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | Accessible | 6 mts Provided | MR |
| | • Gate width | Accessible | 4.5 mts Provided | MR |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 01 | 02 Provided | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.5mts | 208 cm & 122 cm | MR (Old Case) |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | e. No. of continuous staircases to terrace | Required | Provided | MR |
| | f. Width of Corridor | 1.5mts | Provided | MR |
| | g. Door Size | 1 mtrs | 2 x 1m Provided | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 04 nos | 06 Provided | MR |
| | • Types | CO ₂ , ABC type | Provided | MR |
| | • IS marking | ISI marked | Provided | MR |

| | | | | |
|----|--|----|----|----|
| 6 | First-Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor | NA | NA | NA |
| | <ul style="list-style-type: none"> Length of hose reel hose | NA | NA | NA |
| | <ul style="list-style-type: none"> Nozzle diameter | NA | NA | NA |
| 7 | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> Type of detectors | NA | NA | NA |
| | <ul style="list-style-type: none"> Location of Main Panel | NA | NA | NA |
| | <ul style="list-style-type: none"> Location of Repeater Panel | NA | NA | NA |
| | <ul style="list-style-type: none"> Alternate source of power | NA | NA | NA |
| | <ul style="list-style-type: none"> Hooters' Location | NA | NA | NA |
| 8 | MOEFA | NA | NA | NA |
| 9 | Public Address System. | NA | NA | NA |
| 10 | Automatic Sprinkler System. | | | |
| | <ul style="list-style-type: none"> Basement | NA | NA | NA |
| | <ul style="list-style-type: none"> Upper Floor | NA | NA | NA |
| | <ul style="list-style-type: none"> Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer | NA | NA | NA |
| | <ul style="list-style-type: none"> Number of hydrants per floor | NA | NA | NA |
| | <ul style="list-style-type: none"> Hose Box | NA | NA | NA |
| 12 | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants | NA | NA | NA |
| | <ul style="list-style-type: none"> Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level | | | |
| | <ul style="list-style-type: none"> ➤ Discharge of main Pump | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Head of Main pump | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Number of main pumps | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Jockey Pump out put | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Jockey pump head | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Standby Pump out put | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Standby Pump Head | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Pump House Access | NA | NA | NA |
| | <ul style="list-style-type: none"> Terrace level | | NA | |
| | <ul style="list-style-type: none"> ➤ Discharge of pump | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Head of the pump | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Power Supply | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Auto Starting of pump | NA | NA | NA |
| 14 | Captive Water Storage for fire fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Draw-off connection | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Fire service inlet | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Access to tank | NA | NA | NA |
| | <ul style="list-style-type: none"> Overhead Tank capacity | NA | NA | NA |

h

| | | | | |
|----|--|----|----|----|
| | Exit Signage. | NA | NA | NA |
| | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of Lift lobby | NA | NA | NA |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17 | Standby power supply | NA | NA | NA |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Batter backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/WZ/2019/909 dated 29/04/2019 Renewal in accordance with the circular No.F16/Estate/CC/fire safety/2011/3298-3398 dated 01/03/2011 issued by the D.O.E.is recommended.

82/ADO/MN
11/3/2022
21/03/2022

~~DO (west)~~

Where is pump & OH tank, Hose reel etc?

~~dy~~ 14/3

~~Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)~~

~~ADO (MN)~~

In , Inspection of school building h+L Block has been done only, as per D.O.E circular no 3298-3398 there is not any requirement of pump & O.H tank

D.O. (WEST) 438
DATED 21/03/22

~~DO (west)~~

~~dy~~ 21/3

~~ADO (MN)~~

ADO (MN)

Submitted to

~~Signature of the Inspecting Officer
21/03/2022~~