

C-37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F6/DFS/MS/2022 /School/ W2/332

Dated: 29/03/2022

FIRE SAFETY CERTIFICATE

Certified that the **Paradise Public School** located at **A-Block, Indraprasth, Colony, Amrit Vihar, Burari, Delhi-110084** comprised of **Ground and 03 upper floors** owned/ occupied by **Paradise Public School** was issued Fire Safety Certificated vide this office letter no. **F-6/DFS/MS/2016/School/WZ/311** dated **25.02.2016**. The premise was re-inspected by the officer concerned of this department on **04.03.2022** in the presence of **Mr. Laltuna Jha (Manager)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B" for ground and one upper floor only** with effect from **29/03/2022** for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on **29/03/2022** at New Delhi


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph.-011-25156707
D.C.P.

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.
2. The Principal, Paradise Public School located at A-Block, Indraprasth, Colony, Amrit Vihar, Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doiit/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".
- 7 **The use of second and third floor of the building is restricted to residence & personal use only.**

INSPECTION REPORT

1. Name & address of the building : Paradise Public School at A-block, Amrit Vihar, Burari, Delhi-84.
2. Type of Occupancy : Educational
3. Composition of building : Ground +03 upper floors (School is ruining on ground +01 upper floor only)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2016/School/WZ/311 Dated:25.02.2016
6. Fire Safety directives letter No : Director of Education Letter dated 17.01.2005
7. Date of inspection : 04.03.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Mr. Laltuna Jha (Manager)
9. Year of Construction : 2007-2015
10. Applicant's letter No. : Online E-Mail I.D dated: 23.02.2022

Covered Area 700 S.yd

	Minimum Standards on fire prevention and fire safety U/R 33	Director. Of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.17m & 1.05m	MR (old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
e. Width of Corridor	NA	NA	NA	
f. Door Size	1m	1m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	No basement	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			

Sp

	<ul style="list-style-type: none"> Total numbers 	05nos	06nos	MR
	<ul style="list-style-type: none"> Types 	ABC/Co2	ABC-06	MR
	<ul style="list-style-type: none"> ISI marking 	Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	30m	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	5mm	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	225 lpm	225 lpm	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	40m	40m	MR
<ul style="list-style-type: none"> ➤ Power Supply 	Required	Provided	MR	
<ul style="list-style-type: none"> ➤ Auto Starting of pump 	Required	Provided	MR	
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw-off connection 	NA	NA	NA

Qe

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		2000ltr	2000ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular 17.01.2005 the FSC issued vide letter of even no. 311 dated 25.02.2016 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

~~DO (WSP)~~

~~08/03/2022~~

~~ADDO (W2)~~

~~ADDO (W2) ADO/R.N~~

~~ADDO (W2)~~

~~ADDO (W2)~~

Signature of the Inspecting Officer
 Name:- C.L. Meena
 Designation:- ADO/RN

As approved, F.T. letter is put up for your signature Pls.

16/03/2022