

C-24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**


No. F6/DFS/MS/2022/School/WZ/336

Dated: 29/03/2022

FIRE SAFETY CERTIFICATE

Certified that the **Ran Singh Model Public School, E-Block, Pratap Vihar-III, (Opp, Sector-21) Kirari, Rohini, Delhi-110085**, comprised of **Two Blocks, Gr.+01 & Gr.+02 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2018/WZ/2382 dated 23.10.2018**. The premises was re-inspected by the officer concerned of this department on **07.03.2022** in the presence of **Mr. Sunil Kumar (Manager)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational "Group B"** with effect from 29/03/2022 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/03/2022 at New Delhi by


**(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250**

Copy to :-

1. The Director of Education, Old Secretariat, Delhi
2. The Principal, Ran Singh Model Public School, E-Block, Pratap Vihar-III, (Opp, Sector-21) Kirari, Rohini, Delhi-110085.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

INSPECTION REPORT

1. Name & address of the building : Ran Singh Model Public School, E-Block, Pratap Vihar-III, (Opp Sector-21) Kirari, Rohini, Delhi-110085.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**Two Blocks, Gr.+01 & Gr.+02 upper floors**)
4. Details of Previous NOC : F.6/DFS/MS/2018/WZ/2382 dated 23.10.2018
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 07.03.2022
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Sh. Sunil Kumar (Owner)
9. Year of Construction : 2002 & 2011
10. Applicant's letter No. : Online e-mail dated 31.01.2022.

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--------|---|------------------------------------|--|----------------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | Accessible 4.5m NA | Accessible 4.0m NA | MR MR(old case) NA |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floors Basements | 02 NA | 03 NA | MR NA |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floor Basements | 1.5m NA | Gr.+2-1.60m Gr.+1-1.30m & 1.48m NA | MR(old case) NA |
| | c. Protection of exits | | | |
| | Fire check door | | | |
| | <ul style="list-style-type: none"> Pressurization | NA NA | NA NA | NA NA |
| | d. No. of continuous staircases to terrace | Required | Provided | MR |
| | e. Width of Corridor | NA | NA | NA |
| | f. Door Size | 1.0m | Gr.+2-1.05 to 1.12m Gr.+1-1.0m | MR |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers | NA NA NA NA NA | NA NA NA NA NA | NA NA NA NA NA |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> Basements Upper floors | 30 a/c per hour 12 a/c per hour | NA Natural ventilated | NA MR |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 10nos. ABC/CO2 ISI marked | 12nos. ABC-12 Yes | MR MR MR |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | 01 30mm 5m | Provided Provided Provided | MR MR MR |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel | NA NA NA | NA NA NA | NA NA NA |

N/22

Special Fire Protection System for Protection of special Risks, if any:

NA

NA

NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2018/WZ/2382 dated 23.10.2018 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

24/03/2022

~~ADO Rohini~~

F-T letter is put up for kind perusal and signature beam.

DO (NW)

MS/ cell