

432

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2022/NDZ/344

Dated: 30/03/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Hillwoods Academy, G-Block, Preet Vihar, Delhi - 110092, comprised of A Block (G+3) & B Block (G+1) Floors owned / occupied by Hillwoods Academy has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/2018/NDZ/2696 dated 13/12/2018. The premises was re-inspected by the officer concerned of Fire Service on 21.03.2022 in the presence of Mr. Khalil Ahmad and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 30/03/2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 30/03/2022 at New Delhi by.


30/3/22

(Dr. S.K. TOMAR)

DY. CHIEF FIRE OFFICER.

Copy to :-

1. The Principal, M/s Hillwoods Academy, G-Block, Preet Vihar, Delhi - 110092.
2. The Director of Education, Civil Lines, Old Secretariat, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

N/11
INSPECTION REPORT

1. Name & address of the building: Hillwood Academy, G-Block, Preet Vihar, Delhi-110092.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC No. F6/DFS/MS/School/2018/NDZ/2696 dated 13/12/2018
5. Fire Safety directives Letter No. : A Block-F6/DFS/MS/BP/95/1125 DT. 24/07/1995
B Block - F6/DFS/MS/2000/2024 DT. 08/11/2000
6. Date of inspection : 21/03/2022
7. Name of the Inspecting Officer : D.O. (East)
8. Name and designation of Officer from the building side : Mr. Khalil Ahmad
9. Year of Construction : 1995 - 2000
10. Applicant's letter no. : HA/GEN/55/21-22 dated 14/02/2022

A Block (G+3) & B Block (G+1)
Separate from each other

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements Under Guideline	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	6 m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	3	MR
	• Basements	1	1	MR
	Width of staircases			
	• Upper floors	1.50 m	1.70 m each	MR
	• Basements	1.50 m	1.50 m	MR
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	2	2	MR
	c. Width Of Corridor	1.0 m	1.2 m	MR
	d. Door Size	1.0 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	22	30	MR
	• Types	ABC /Co ₂	Provided	MR
	• IS marking	ISI Marked	Provided	MR

6.	First - Aid Hose Reels			
	• Total numbers on each floor	3	2 nos. of in G+2 & 1 no. in G+1 Block	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	02 no.	02 no.	MR
	• Hose Box	02 no.	02 no.	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	900 LPM	MR
	➤ Head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	50,000 Ltrs.	50,000 Ltrs.	MR
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR

N113


15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:- **General requirements for schools as per Director of Education circular dated 01/03/2011 / NBC (Part-IV)**

1. Escape route:- Clear
2. LPG cylinders in laboratories :- Nil
3. Electric wiring:- Conduit Wiring MCB and ELCB.....
Electric circuit:- MCB Provided
4. Electric meter board / switch board panel.:-Not Under the staircase
5. Basement use as per BBL 1983 :- N/A
6. Emergency telephone no. board :- Displayed
7. Generator set :- at the terrace

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2018/NDZ/2696 dated 13/12/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



By CFO/NDZ

(Signature)
28/3/22

(Signature)

F.T. is added for signature please.

(Signature) By CFO/NDZ

(Signature)
20/3/22

(Signature)
25/3/22
Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : Divisional Officer (East)

(Signature)
29/03/22