

469

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022/School/342

Dated: 30/03/2022

FIRE SAFETY CERTIFICATE

Certified that the building M.D.H International School (An institute of Mahashya Chuni Lal Charitable Trust) Located at Plot No 3, Pocket – 2, Sector – 6, Dwarka, New Delhi – 110075 comprised of Ground + 03 Upper Floors owned / occupied by MDH International School was issued FSC vide Letter No. F6/DFS/MS/School/2019/SZ/194 Dated 25/01/2019. The premises was re inspected by the officers concerned of this department on 21/03/2022 in the presence of Sh. R.K Wadhera (Manager) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B “Educational building” with effect from 30/03/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/03/2022 at New Delhi by.

(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054
2. The Principal, M.D.H International School Located at Plot No 3, Pocket – 2, Sector – 6, Dwarka, New Delhi – 110075

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/22

INSPECTION REPORT

1. Name & address of the building: M.D.H International School (An institute of Mahashya Chuni Lal Charitable Trust) Located at Plot No 3, Pocket - 2, Sector - 6, Dwarka, New Delhi - 110075.
2. Type of Occupancy : Educational (Ground+ 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2019/SZ/194 Dated 25/01/19
5. Fire Safety directives L. No. : F6/DFS/MS/BP/2002/1659 dated 19/09/2002
6. Date of inspection : 21/03/2022
7. Name of the Inspecting Officer : Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. R.K Wadhera (Manager)
9. Year of Construction : Before 2002
10. Applicant's letter No. : MDH/Mis/22/583 dated 02/03/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement as per N/14, N/15&N/16	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06mtrs	Provided	MR
	• Gate width	4.5mtrs	Provided Old case	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	Provided	MR (Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	2 Nos	Provided	MR
	e. Width Of Corridor	1.5 mtr	Provided	MR
	f. Door Size	01 mtr	Provided	MR(old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

16

N/23

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA Required	NA Natural ventilation provided	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	17 nos. ABC & CO ₂ ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA NA NA	100 mm 01 Provided	NA NA NA
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA

N/24

13	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 lpm	Provided	MR
		30Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	50,000 ltr	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000Ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

N/25

20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel	MR
----	--	----------	--	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2019/SZ/194 Dated 25/01/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- The Porta cabin constructed at terrace has been removed as shown in photographs. (C/6040/64)

~~17/10~~
22/3/21

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ADD/DW/17

~~DD/DW/17~~

Signature
 20/6/2022

Dy. Insp. (S2)

Signature

ADD (DW/17)

bir pt letter is put up for sig late

~~17/10~~
29/3/22

~~Dy. Insp. (S2)~~

Signature

MS. 10/11