

E-41

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/EH/WZ/2022/ 72

Dated: 28/03/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s. Sandoz Restaurant R.G running at ground floor in a building comprised of Basement, Ground plus Three Upper Floors located at Plot No.- 05, Vishal Enclave, Raja Garden, New Delhi- 110027. The premise was re-inspected by the officer concerned of this department on 14.03.2022 in presence of Sh. Jeewan Bisht, liaison manager and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class Assembly Group- D (restaurant) (**Ground Floor Only**) with effect from 28/03/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 28/03/2022 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Service
West Zone

Copy to:-

1. The Owner/occupier, M/s. Sandoz Restaurant, GF, Plot No.- 05, Vishal Enclave, Raja Garden, New Delhi- 110027.
2. The Deputy Health Officer, SDMC, Shivaji Enclave, Rajouri Garden, New Delhi- 27.
3. The Joint Commissioner of Police, Licensing unit, 1st Floor, Police Station Defense Colony, New Delhi.

CONDITIONS

1. The Fire Safety Certificate is valid for Ground Floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
4. The trained firefighting staffs should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. All the means of escapes /exits shall not be locked/bolted/blocked at any time for safe evacuation of the occupants in case of any emergency.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: M/s. Sandoz Restaurant R.G., Plot No. C-5, Vishal Enclave, Raja Garden, New Delhi- 110027.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/EH/2019/403 dated 13.02.2019
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 14.03.2022
7. Name of the Inspecting Officer : M.K. Chattopadhyay, DO (West)
8. Name and designation of Officer
From the building side : Sh. Jeewan Bist, Liaison Manager
9. Year of Construction : 2018
10. Applicant's email date : Online ID 2021090119691

M/s. Sandoz Restaurant is running on Ground Floor in a building comprised of basement, ground plus three upper floors.

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/UBBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtrs 5 mtr NA	Provided Provided NA	MR MR NA
2.	Number, width, Type & Arrangements of exits:			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	01 x 2.0 m, 01 x 1.35 m	2.40, 1.40 mts	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Provided	MR

N-9

5.	Fire Extinguishers		Provided	MR
	<ul style="list-style-type: none"> Total numbers Types IS marking 	06 nos. DCP & CO ₂ ISI marked	Provided Provided Provided	MR MR MR
6.	First - Aid Hose Reels		Provided	MR
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	Smoke Provided Provided Provided Provided	NA NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	Provided NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA NA NA	150 mm Provided Provided	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 450 lpm 40 m Required Required	NA NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for firefighting:			
	<ul style="list-style-type: none"> Underground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 20,000 litres	NA NA NA NA Provided	NA NA NA NA MR
15	Exit Signage	Required	Provided	MR


16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/GH/2014/NDZ/934 dated 28.07.2014, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


DFA is put up for approval & signature please.

D.O. (WEST)/377-W
DATED: 23/02/2022


23/3/2022

Signature of the Inspecting Officer
Name: M.K. Chattopadhyay
Designation: DO (West Division)


~~DCFO (W2)~~



24/2/2022

~~DO West~~

F.T. letter is put up for Sign please

~~DCFO (W2)~~


28/2/2022


28/3/2022

west cell

FSC uploaded on MHA Portal
30/3 Sanjeev

T