

G 3

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001


No.F6/DFS/MS/School/SZ/2022/ 341

Dated: 30/03/2022

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Middle School located at Gaddha Colony, Jaitpur Extn., Part-II, New Delhi-44 (School ID no. 1925442), comprised of Ground + 01 Upper floor owned/occupied by Sarvodaya Middle School has complied with the fire prevention and fire safety requirements in accordance with the circular no. F6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and verified by the officers concerned of Delhi Fire Service on 22.03.2022 in the presence of Mr. R.P. Meena (Vice Principal) and found that the school building (Ground + 01 Upper floor) is fit for occupancy of Group B "Educational Building" with effect from 30/03/2022 for a period of three years, subject to conditions printed below.

Issued on... 30/03/2022 ...at New Delhi by


(Anil Garg)
Director
Delhi Fire Service
e/c Anil
30/3

Copy to:-

1. The Director of Education, South MCD, S.P.M., Civic Centre, New Delhi.
2. The Principal, Sarvodaya Middle School located at Gaddha Colony, Jaitpur Extn., Part-II, New Delhi-44 (School ID no. 1925442).

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Sarvodaya Middle School located at Gaddha Colony, Jaitpur Extn., Part-II, New Delhi-44 (School ID no. 1925442)				
2	Building is comprised of	Ground + 01 upper floor				
3	Type of occupancy	Group B –Educational Building				
4	Type of case	New case				
5	Details of previous FSC	Nil				
6	Fire safety direction letter no.	F6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011				
7	Date of inspection	22.03.2022				
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M.Road)				
9	Name of the designation of officer from the building side	Mr. R.P. Meena (Vice Principal)				
10	Year of construction	2021				
11	Applicant's letter no.	Letter no. dated				
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per DOE Circular dated 01.03.2011	Provided at site	Remarks MR/NMR		
1	Access to Building:					
	A	Road width	6 mtrs.	6 mtrs.	MR	
	B	Gate width	NA	NA	NA	
	C	Width of internal road	NA	NA	NA	
2	Number, Width, Type and Arrangement of Exits:					
	A	Number of staircases				
		a	Upper floor	03 nos.	3 nos.	MR
		b	Basement	NA	NA	NA
	B	Width of staircases				
		a	Upper floor	1.5 mtrs. each	1.5 mtrs each	MR
		b	Basement	NA	NA	NA
	C	Protection of exits				
		a	Fire check door	NA	NA	NA
		b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	01 nos.	02 nos.	MR	
	E	Width of corridor	1.5 mtrs.	1.5 mtrs.	MR	
	F	Door size	1 mtrs.	1 mtrs.	MR	
3	Compartmentation:					
	A	Fire check door	NA	NA	NA	
	B	Sealing of electrical shafts	NA	NA	NA	
	C	Fire rating of shaft door	NA	NA	NA	
	D	Water curtain	NA	NA	NA	
	E	Fire dampers	NA	NA	NA	
4	Smoke Management System:					
	A	Basement	NA	NA	NA	
	B	Upper floor	NA	NA	NA	

5.	Fire Extinguisher:				
	A	Total numbers	08 nos.	08 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	Required	Provided	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	NA	NA	NA
	B	Length of hose reel hose	NA	NA	NA
	C	Nozzle diameter	NA	NA	NA
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	NA	NA	NA
	B	Location of main panel	NA	NA	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	NA	NA	NA
	E	Hooters	NA	NA	NA
8	MOEFA:		NA	NA	NA
9	Public Address System:		NA	NA	NA
10	Automatic Sprinkler System:				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:				
	A	Size of riser/down-comer	NA	NA	NA
	B	Number of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants:				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	NA	NA	NA
	B	Head of main pump	NA	NA	NA
	C	Number of main pumps	NA	NA	NA
	D	Jockey pump out put	NA	NA	NA
	E	Jockey pump head	NA	NA	NA
	F	Standby pump out put	NA	NA	NA
	G	Standby pump head	NA	NA	NA
	H	Auto starting /manual stopping	NA	NA	NA
	I	Pump house access	NA	NA	NA
2	Terrace Level				
	A	Discharge of pump	NA	NA	NA
	B	Head of the pump	NA	NA	NA
	C	Power supply	NA	NA	NA
	D	Auto starting of pump	NA	NA	NA


14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	NA	NA	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
D	Access to tank	NA	NA	NA
E	Overhead tank capacity	NA	NA	NA
15	Exit Signage:	Required	Provided	MR
16	Provision of Lifts:			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17	Standby Power Supply:	NA	NA	NA
18	Refuge Area:			
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
19	Fire Control Room:			
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	PA system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA		NA

Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

Educational building below the height of 09 meters are not covered under Rule 27 of DFS Rules 2010. However fire safety requirements for the same have been issued under Director of Education, Circular no. F6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011. This inspection has been conducted based on the fire safety requirements of the said circular.

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to Fire Safety Certificate under the circular no. 3298 to 3398 dated 01.03.11.


24/3/22

Signature of the Inspecting Officer

Name Rajesh Kumar Shukla


Designation ADO (M. Road)

DO (SD)


26/03/22



C.F.O. (an electric)


26/03/22

