



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2022/340

Dated: 29/03/2022

FIRE SAFETY CERTIFICATE

Certified that Sarvodaya Kanya Vidyalaya, Rajouri Garden Main, New Delhi-110027, comprised of ground plus three upper floors only (newly constructed block) was inspected by the officer concerned of Delhi Fire Service on 24.03.2022 in the presence of Sh. Karnail Singh (Supervisor), and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with Delhi Fire Service Act 20007 and Rules 2010 and that the building/premises is fit for occupancy class "Educational" with effect from 29/3/2022 for a period of 03 years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed blow

Issued on 29/03/2022 at New Delhi by.

(Handwritten signature)
(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Principal, Sarvodaya Kanya Vidyalaya, Rajouri Garden Main, New Delhi- 110027.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.
3. The Asssistant Engineer (E), Sub-Div- 1 Education Division M 1 (N), PWD GNCT, Govt. of Delhi, ITI Campus, Pusa Road, New Delhi- 110012

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya, Rajouri Garden Main, New Delhi - 110027
2. Type of Occupancy : Educational
3. Building Composition : Building comprised ground plus three upper floors only
4. Type of Case : New Case
5. Details of previous NOC : N/A
6. Fire Safety directives letter No : N/A
7. Date of inspection : 24.03.2022
8. Name of the Inspecting Officers : P.V. Rathee, Asstt. Div. Officer (SRD)
9. Name and designation of officers from the building side : Sh. Karnail Singh (Supervisor)
9. Year of Construction : 2020
10. Applicant's letter No. : 54(SPS School)/PWD Edu.Sub-Divn M1-1(N)/2021-22/7 dated 28.02.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	4.5 mts Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02	02	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.50 mts each	1.80 mts each	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02	02Nos.	MR
	g. Width of Corridor	1.5 mts	1.80 mts	MR
	h. Door Size	1.20 mts	1.22 mts at each class room	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural Ventilation	MR

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	12 nos.	Provided	MR
		ABC type	Provided	MR
		ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	03	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7	Automatic fire detection and alarming system Not required			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
N/A		N/A	N/A	
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
	13	Pumping Arrangements		
<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 		---	----	-----
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	450 LPM × 2	Provided
N/A	40 mts each	40 mts	MR	
N/A	Required	Provided	MR	
N/A	Required	Provided	MR	
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000 lts.	10,000 lts.	MR
Required	Provided	MR		
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.	Not Applicable		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked at random and found satisfactory at the time of inspection.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the Rules, it is recommended to grant fire safety certificate under Delhi Fire Service Act- 2007 & Rules- 2010.

Accordingly, DFA is put up for approval & signature please.

This FSC is for newly constructed Block.

DO (FW)

*MS
25/13/22*

*Director (F2)
25/13*

C.F.O. (on leave)

*Director (M)
25/03/22*

Signature of the Inspecting Officer
(P.V. Rathee)
Asstt. Div. Officer, (SRD)

24/13/22

Ansry 4