



CF46

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2022/School/ 343

Dated: 30/03/2022

**FIRE SAFETY CERTIFICATE**

Certified that the Sarvodaya Kanya Vidhalaya No-2, Located at Palam Village, New Delhi – 110045 having three blocks BL-A=Ground floor (**Pota cabin**) , BL-B=G+1UF & BL-C=G+3UF, was issued FSC vide Letter No. F6/DFS/MS/School/2015/SZ/646, Dated-30/04/2015. The premises was re inspected by the officer concerned of this department on 23/02/2022 in the presence of Mr. Gajraj Singh (Estate Manager) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B “Educational building” with effect from 30/03/2022 for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/03/2022 at New Delhi by.

(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service.

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal, Sarvodaya Kanya Vidhalaya No 2, Palam Village, New Delhi – 110045.(School- ID-1821015)

**Following fire safety directives must be adhered to:-**

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/16  
**INSPECTION REPORT**

1. Name & address of the building: Sarvodaya Kanya Vidhalaya No 2, Located at Palam Village, New Delhi – 110045.
2. Type of Occupancy : Educational (03 Blocks= BL-A=GF(**Pota cabin**), BL-B=G+1UF & BL-C=G+3UF,
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2015/SZ/646 Dated-30/04/2015
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 23-02-2022
7. Name of the Inspecting Officer :Udai vir Singh, ADO (DWK)
8. Name and designation of Officer  
from the building side : Ms. Sunita Sikri (HOS)
9. Year of Construction : Old block Before 2010 & New block 2011
10. Applicant's letter No. : Email Dated 10/02/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/4	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06mtrs	18 mtrs	MR
	• Gate width	4.5mtrs	Provided	MR Old case
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 each block	02 each block	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	BL-B=159cm &143cm BL-C=2x145cm	MR(Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	01 No each block	MR
	e. Width Of Corridor	1.5 mtr	240cm &165cm	MR(Old Case)
	f. Door Size	Required	90cm 104cm	MR(Old Case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA



N/17

4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	NA	NA	NA
		12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	02 Nos each floor ,per block ABC & CO <sub>2</sub> ISI marked	14 Nos. ABC & CO <sub>2</sub> Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	Required in Each Block	01	MR
		30m	30 m	MR
		5mm	05 mm	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	100 mm	NA
		NA	NA	NA
		NA	Provided	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA

13	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	2x450 lpm	MR
		Required	35 mtr	MR
		Required	Provided	MR
		NA	NA	NA
14	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	Provided	NA
		NA	NA	NA
		Required	10,000 ltr	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Battery backup</li> <li>➤ Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

W/19

20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
----	--------------------------------------------------------------------------	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2015/SZ/646 Dated-30/04/2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Signature of the Inspecting Officer~~  
 Name Dey Nro Singh  
 Designation ADD/DWK

DDO/SZ      MS  
 2/3/22

Dyefo (SZ)      E-1  
MS

ADD/DWK

Sir At letter is put up for sig b14

Dyefolsz      MS      MS      MS  
 2/13