

EST

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[See sub-rule (1) of rule 35]  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/2022/NDZ/356

Dated: 01/04/2022

**FIRE SAFETY CERTIFICATE**

Certified that the Abhinav Bharti Model School located at Gali No. 12, Part-III, C-Block, II<sup>nd</sup> Pusta, Sonia Vihar, Delhi-110090, comprised of Ground & Two Upper Floor owned / occupied by Abhinav Bharti Model School, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/NDZ/827 dated 25/04/2018. The premises was re-inspected by the officer concerned of Fire Service on 29/03/2022 in the presence of Mr. D.N. Sharma and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular letter No. 262-362 dated 17/01/2005 issued by Director of Education and observed that the building is fit for occupancy class "Educational" (Group-B) with effect from 01/04/2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 01/04/2022 at New Delhi by

  
11/4/22

**(Dr. S.K. TOMAR)**  
**DY. CHIEF FIRE OFFICER.**

Copy to :-

1. The Principal, Abhinav Bharti Model School, Gali No. 12, Part-III, C-Block, II<sup>nd</sup> Pusta, Sonia Vihar, Delhi-110090.
2. The Joint Director of Education, (Land & Estate), Lucknow Road, Delhi-110054.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in).

2/16  
**INSPECTION REPORT**

1. Name & address of the building: Abhinav Bharti Model School, Gali No. 12, Part-III, C-Block, 11<sup>th</sup> Pusta, Sonia Vihar, Delhi-110090.
2. Type of Occupancy : Educational
3. Building Comprised of : Ground & Two Upper Floors only
4. Type of Case : Renewal
5. Details of previous NOC No. : F6/DFS/MS/School/2018/NDZ/827 dated 25/04/2018
6. Fire Safety directives Letter No. : Circular letter No. 262-362 dated 17/01/2005
7. Date of inspection : 29/03/2022
8. Name of the Inspecting Officer : D.O. (East)
9. Name and designation of Officer from the building side : Mr. D.N. Sharma
10. Year of Construction : 2008
11. Applicant's letter received through : email dated 22/03/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	Old Cir dated 17/01/05 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	6m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	2	MR
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	1.50m	1.00m & 0.90m	MR
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	1	Provided	MR
	c. Width Of Corridor	1.5m	Provided	MR
	d. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	6	6	MR
	• Types	ABC /Co2	ABC / Co2	MR
	• ISI marking	ISI Marked	ISI Marked	MR

*(Handwritten Signature)*

6.	First - Aid Hose Reels			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	1	1	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450LPM	450LPM	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5000 Liters	Provided	MR

1817  
30/3/20

*[Handwritten signature]*

M/118

		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	NR	NR	NR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Battery backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2018/NDZ/827 dated 25/04/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Dy. CEO (NDZ)

*[Signature]*  
30/3/22

*[Signature]*

F.T. is added fl.

Dy. CEO (NDZ)

*[Signature]*  
11/4/22

pas

*[Signature]*  
29/03/2022

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : Divisional Officer (East)