

G-26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2022 / School / WZ / 345


Dated: 31/03/2022

FIRE SAFETY CERTIFICATE

Certified that **The Mann School** located at **Holambi Khurd, Delhi-110082** comprised of **02 Blocks-(Ground and two upper floors)** owned/occupied by **The Mann School** was issued FSC by this department vide letter No **F-6/DFS/MS/2019/696** dated 02.04.2019. The building was re-inspected by the officer concerned of this department on 24.03.2022 in the presence of Sh. Saurabh (Admin. Officer), and observed that all the fire prevention and fire safety arrangements as provided in the building found in good working condition. The premises have deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy **Group B Educational** with effect from 31/03/2022 for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/03/2022 at New Delhi

Yours faithfully



(Dharampal Bhardwaj)
Dy. Chief Fire Officer
WEST ZONE



Copy to :-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.
2. Principal, The Mann School, Holambi Khurd, Delhi-82.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : The Man School , Holambi Khurd, Delhi-110082.
 2. Type of Occupancy : Educational
 3. Building Comprised : Two Blocks-(Ground+Two upper floors)
 4. Type of Case : Renewal
 5. Details of Previous NOC : Letter No. F.6/DFS/MS/2019/696 Dated-02/04/2019
 6. Fire Safety directives letter No : DOE Circular dated 17.01.2005 & NBC Part-IV
 7. Date of inspection : 24/03/2022
 8. Name of Inspecting Officer : ADO (BW)
 9. Name and designation of officers
 From the building side : Sh. Saurabh (Admin. Officer)
 10. Year of Construction : 1989 & 2005
 11. Applicant's letter No. : Nil , Dated-14/03/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education letter	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	9.0 m	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	03 m	Provided	MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	05	05	MR
	• Basements	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	• Upper Floor	1.50 m in each block	A Block-1.5 m×3 B-Block-1.50 m & 1.20 m	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	04	Provided	MR
	f. Door Size	2 m	2 m	MR
		1 m	1 m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA

N-21

	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	25	40	MR
		ABC	ABC	MR
6.	First-Aid Hose Reels	Yes	Yes	MR
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	04	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

(Signature)

N-22

	<ul style="list-style-type: none"> ➤ Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	<p>—</p> <p>450 lpm×2</p> <p>40 m</p> <p>NA</p> <p>—</p> <p>NA</p>	<p>—</p> <p>450 lpm×2</p> <p>40 m</p> <p>NA</p> <p>—</p> <p>NA</p>	<p>—</p> <p>MR</p> <p>MR</p> <p>NA</p> <p>—</p> <p>NA</p>
14. Captive Water Storage for fire fighting				
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>10,000 ltrs×2</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>10,000 ltrs×2</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>MR</p>
15.	Exit Signage.	Required	Provided	MR
16. Provision of Lifts.				
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>
17.	Standby power supply	NA	NA	NA
18. Refuge Area.				
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
19. Fire Control Room				
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

Signature

--	--	--	--	--

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended for renewal of Fire Safety Certificate issued vide letter no.F-6/DFS/MS/2019/696 under rule 35 of the Delhi Fire Service Rules 2010.

~~Do (West)~~

~~DCO (N2)~~
 26/3/2022
 29/3/2022

~~Do (B.W)~~
 ADO (B.W)
 25/3/22

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.

D.O. (WEST)/JIT
 DATED-25/3/2022

~~ADO/B.W~~ F-T letter is put up for samples

~~Do~~
 ADO (B.W)
 29/3/22

MS/cell