

E19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6 /DFS /MS /School/2022 / W2 | 354

Dated: 31 / 03 / 2022

FIRE SAFETY CERTIFICATE

Certified that the **Bhartiya Vidyalaya (Govt. Aided)** located at **Sindhora Kala, Shakti Nagar Extension, Delhi-110052** comprised of **Ground floor only** owned/ occupied by **Bhartiya Vidyalaya (Govt. Aided)** was issued Fire Safety Certificated by this department vide letter no. **No.F6/DFS/MS/07/2433 dated 03.09.2007**. The premises was re-inspected by the officer concerned of this department on **13.03.2022** in presence of **Mrs. Preeti Bhagat (Principal)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 262-362 dated 17.01.2005 and the building/ premise is fit for occupancy class **Group B Educational** with effect from **31.03.2022** for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **31/03/2022** at New Delhi


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-25156707

HC Q

Copy to : -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, Bhartiya Vidyalaya (Govt. Aided) located at Sindhora Kala, Shakti Nagar Extension, Delhi-110052.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

114
INSPECTION REPORT

1. Name & address of the building : Bhartiya Vidyalaya, Sindhora Kalan, Shakti Nagar Extn., Delhi-110052.
2. Composition of building : Ground floor only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/07/2433 Dated: 03.09.2007
6. Fire Safety directives letter No : Director of Education Circular dated 17.01.2005
7. Date of inspection : 13.03.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Mrs. Preeti Bhagat (Principal)
10. Year of Construction : 1985
11. Applicant's letter No. : Letter No. BV/2021-22/701 Dated- 24.02.2022

Covered Area: 311 sq.y class rooms - 07nos students - 75nos

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	1 m	1 m	MR
	f. Door Size			
	3	Compartmentation.		
• Fire check door		NA	NA	NA
• Sealing of electrical shafts		NA	NA	NA
• Fire Rating of shaft door		NA	NA	NA
• Water Curtain		NA	NA	NA
• Fire Dampers		NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	02nos	03nos	MR

88

	<ul style="list-style-type: none"> Types ISI marking 	ABC/CO2	ABC-03	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		N/A	NA	N/A
		N/A	NA	N/A

we
rec
cer

14	Captive Water Storage for fire fighting.				
	• Underground tank capacity	NA	NA	NA	
	➤ Draw-off connection	NA	NA	NA	
	➤ Fire service inlet	NA	NA	NA	
	➤ Access to tank	NA	NA	NA	
	• Overhead Tank capacity	NA	NA	NA	
15	Exit Signage.		N/A	N/A	N/A
16	Provision of Lifts.				
	• Pressurization of Lift Shaft	N/A	N/A	N/A	
	• Pressurization of Lift lobby	N/A	N/A	N/A	
	• Communication In lift Car	N/A	N/A	N/A	
	• Fireman's Grounding Switch	N/A	N/A	N/A	
	• Lift Signage	N/A	N/A	N/A	
17	Standby power supply		N/A	N/A	N/A
18	Refuge Area.				
	➤ Total Area	N/A	N/A	N/A	
	➤ Location	N/A	N/A	N/A	
19	Fire Control Room				
	• Detector System Panel	N/A	N/A	N/A	
	• Flow Switch Panel	N/A	N/A	N/A	
	• PA System Panel	N/A	N/A	N/A	
	• Batter backup	N/A	N/A	N/A	
	• Building Floor Plans	N/A	N/A	N/A	
20	Special Fire Protection Systems for Protection of special Risks, if any:		N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 17.01.2005, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 2433 dated 03.09.2007.

DO (M/W)

by C.L. Meena
15/03/2022

27/03/2022

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation :- ADO/RN

ADO/RN

As approved, F.T. letter is put up for your signature please.

25/03/2022 (cont...)