

C-55

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2022/School/383

Dated: 06/04/2022

FIRE SAFETY CERTIFICATE

Certified that the building St. Gregorios School, Located at, Sector-11, Dwarka, New Delhi-110075, comprised of Ground + 4 Upper floors owned / occupied by St. Gregorios School, was issued FSC vide Letter No. F6/DFS/MS / SZ /2021/421 Dated-02/07/2021 **(Issued to G+3UF)** and have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 25/03/2022 in the presence of Father John Samuel and that the premises is fit for occupancy class-B "Educational" with effect from 06/04/2022 for a period of three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010..

Issued on 06/04/2022 at New Delhi by.


(Atul Garg)
Director,
Delhi Fire Service.

Copy to:

1. The Principal St. Gregorios School, Sector-11, Dwarka, New Delhi-110075
2. Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/20

INSPECTION REPORT

1. Name & address of the building: St. Gregorios School, Located at, Sector-11, Dwarka, New Delhi-110075.
2. Type of Occupancy : Educational (Ground+ 04 Upper Floors)
3. Type of Case : New
4. Details of previous NOC : F6/DFS/MS / SZ /2021/421 Dated-02/07/2021
(Issued to G+3UF)
5. Fire Safety directives Letter No. : DOE Circular No. 262-263 Dated 17/01/2005 & F6/DFS/MS/BP/2018/117 Dated 25/04/2018
6. Date of inspection : 25-03-2021
7. Name of the Inspecting Officer :DO/SW & ADO (DWK)
8. Name and designation of Officer
from the building side :Father John Samuel
9. Year of Construction : 2009 & 2019
10. Applicant's letter No. : Email Dated 16/03/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 M	Provided	MR
	• Gate width	6 M	Provided	MR
	• Width of internal road	6 M	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04 Nos.	04 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02 Nos.	Provided	MR
	e. Width Of Corridor	1.5 mtr	Provided(Old Case)	MR
	f. Door Size	Class Room Doors=1 m	01 mtr	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 Nos. ABC & CO ₂ ISI marked	25 Nos. ABC & CO ₂ ISI marked	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 30m 5mm	02 30m 5mm	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm 02 02	100 mm 02 02	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 900 LPM 40Mtr Required Required	NA NA NA NA NA NA NA NA NA NA NA Provided 40Mtr Provided Provided	NA NA NA NA NA NA NA NA NA NA MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA NA NA NA 25,000Ltr	NA NA Provided NA Provided	NA NA NA NA MR
15	Exit Signage	Required	Provided	MR




4/22

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	D.G Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	CO2 fire extinguisher provided near electric panel	MR


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.


Note:- The width of some rooms at 4th floor is less than 1.2m such rooms may not use for school activities.(Undertaking Placed at C/ 52)

 29/3/22

Sign of Inspecting Officer
Name Sh Vedpal
Designation DO/SW

 28/3/22

Sign of Inspecting Officer
Name Udai Vir Singh
Designation ADO/DWK

 (52)



C.F.O. on Leave

~~Director~~ 11/4/2022

DO/SW 11/4/22

ADO (Dwarka)