

427

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2022/SZ/ 147

Dated: 04/04/2022

FIRE SAFETY CERTIFICATE

Certified that **Delhi Public School**, located at Sector-XII, R.K Puram, New Delhi - 110022 comprised of **Nine Academic Blocks namely A, B C (Interconnected) & Circular Block: Each G+02, D, F & Blossom Block (D Block interconnected with Circular & Blossom Blocks) Each B+G+3, E & Health Block: Each B+G+2 upper floors & one Science/Adm Block** owned/ occupied by Delhi Public School was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/2566 Dt. 28/11/2018. The said premises was re-inspected by officer concerned of this department on 23/03/2022 in presence of Sh. A. S Bhati (Admn) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Education Building**" **Group-B (School)** as above with effect from 04/04/2022 for a period of **Five years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 04/04/2022 at New Delhi by


(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, Delhi Public School, at Sector-XII, R.K Puram, New Delhi - 110022
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

NO. F6/DFS/MS/2022/School/SZ/ 156

Dated: 05/04/2022

Corrigendum

In partial modification to the fire safety certificate (FSC) issued by this department letter of even no- F.6/DFS/MS/School/2022/SZ/147 dated 04/04/2022, the para mentioned in "effect from 04/04/2022 for a period of **Five years** in accordance with rules 36 unless renewed" may be read as "effect from 04/04/2022 for a period of **Three years** in accordance with rules 36 unless renewed". Other contents of the FSC remain unchanged.

Yours faithfully



(Sunil Chawdhary)
DY. Chief Fire Officer
Delhi Fire Service

etc

Copy to:-

1. The Principal, Delhi Public School, at Sector -12, R.K Puram, New Delhi-110022.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

N/16

INSPECTION REPORT				
1	Name & Address of the Building	Delhi Public School, Sector- XII, R.K Puram, New Delhi 110022		
2	Type of Occupancy	Education Building (School)		
3	Building Comprised of	A, B & C Bk: G+2 Each (Interconnected) D & F Bk: B+G+3 (Bk-D) Interconnected with Circular & Block: G+2, Blossom Block: B+G+3, Health Block: B+G+2, Science/Adm Block (A, B, C D & E all are interconnected through skyway).		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2018/SZ/2566 Dt. 28/11/2018		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/87/1863 Dated 10/11/1987		
7	Date of Inspection	23/03/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. A. S Bhati (Admn)		
10	Year of construction	1972, 1982, 1992, 2002		
11	Applicant letter No.	DPSR/DFS/FF/NOC/4-22 dated 28 th Jan 2022		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible	9 mtr	MR
		NA	4.5 mtr	NA
		NA	6 mtr	NA
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 No each Bk	Provided	MR
	➤ Basement floor.	02 No each Bk	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.50 m/ 0.75 m	BK:- 1.22m (GF-SF) & 1.35m (iron) (FF-SF) BK-B: 1.222m (GF-SF) & 1.35 (iron) (FF-SF) Bk-D 1.27m (GF-Terrace) Bk-E 1.10m & 1.53m Bk-F 1.08, 180m, (GF-SF) & 1.35m (iron) (SF-TF) Cir. Bk: 1.06m & 1.36m Blossom Bk:- 1.32m & 1.40 m, Health Bk- 1.20 & 1.35 (iron)	MR (old case)
	➤ Basement floor	1.50 m/ 0.75 m	BK-D- 1.30m, 1.22m, 0.86m, BK-E- 1.10m 1.70m, Bk-F 1.7m, 1.5m Blossom Bk- 1.50 & 1.47m, Health BK- 0.86m, & 1.20 m	MR (old case)
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	01 mtr	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
4.	Smoke Management system.			

	<ul style="list-style-type: none"> Basement Upper floors 	30 ACPH	Exhaust fan Provided	MR
5.	Fire Extinguishers.	12 ACPH	Natural Ventilation	MR
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	Required	40 Nos	MR
		ABC / wco2	ABC / wco2 Type	MR
6.	First Aid Hose Reels.	ISI mark	Provided	MR
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	01 Nos (each)	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	NA	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		NA	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	Required	100 mm	MR
		Required	01 No	MR
		Required	01 No	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	Required	11 No	MR
		Required	11 No	MR
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump house access. 	900 LPM	1200 LPM	MR
		45m	45 m	MR
		01	01	MR
		240 LPM	Provided	MR
		45m	Provided	MR
		900 LPM	Provided	MR
		45m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	A, B, C Bk-450 LPM D, E, F Bk- 900 LPM Hth & Blm- 900 LPM	900 LPM x 2 Nos 900 LPM x 2 Nos 900 LPM x 2 Nos	MR
		40 mtr each	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	1,00,000 ltrs	1,00,000 ltrs	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		A, B, C Bk- 10,000 ltrs D, E, F Bk- 15,000 ltrs	20,000 ltrs	MR

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2018/SZ/2566 Dt. 28/11/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer
 Name: Sh. Rajesh Kumar
 Design: ADO (BCP)

14/25/3/2022

DO (SD)

dir
24/03/22

Dy C/O (S2)

F.T.

ADO (BCP)

As approved, F.T. letter is put up for your signature pl

14/01/04/2022

Dy C/O (S2)