

225

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**


No. F.6/DFS/MS/School/2022/SZ/ 395

Dated: 07.04.2022

**FIRE SAFETY CERTIFICATE**

Certified that **Delhi Public School** located at **East of Kailash, New Delhi -110065** comprised of 04 interconnected Blocks, A & C Blocks- Ground plus One upper Floors, B & D Blocks- Ground Plus Two Upper Floors owned/occupied by Delhi Public School was issued FSC by this department vide letter No. F6/DFS/MS/School/2019/SZ/731 dated 05/04/2019. The premises was re-inspected by officer concerned of this department on 06/04/2022 in presence of Mr. Augustine (Manager) and observed that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational Building**" Group-B, (School) with effect from 07/04/2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/04/2022 at New Delhi by



(SUNIL CHAWDHARY)

DY. CHIEF FIRE OFFICER (SZ)



Copy to: -

1. The Principal, Delhi Public School located at East of Kailash, New Delhi -110065
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

N/13

**INSPECTION REPORT**

1	Name & Address of the Building	Delhi Public School, East of Kailash, New Delhi-110065		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	School has Four Building Blocks interconnected at 1 <sup>st</sup> Floor through corridor. Block A & C : G+1, Block B & D : G+2		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2019/SZ/731 dated 05/04/2019		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	06/09/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Augustine (Manager)		
10	Year of construction	1980		
11	Applicant letter No.	DPSR/DFS/FF/MOC/3-22 dated 28/01/2022		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC Requirement</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	Required	Approachable	MR
	• Gate width	Required	4.75m, 2.60m & 2.10m	MR
	• Width of internal road	-NA-	-NA-	-NA-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	01 Nos each	Total 04 Nos	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.5 mtr	1.44m, 1.35m, 1.30m & 0.80m	MR (old case)
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	01 No	03 Provided	MR
	<b>e) Width of corridor</b>	1.5m	Provided	MR
	<b>f) Door size</b>	1 mtr	Provided	MR
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
<b>4</b>	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
<b>5</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	100 Nos	MR
	• Types	ABC/CO2	ABC & Co	MR
	• ISI Marking	ISI mark	Provided	MR
<b>6</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	06 at GF & 04 at UFs	Provided	MR



M/15

19	<b>Fire Control Room.</b>			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			
The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.				
Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/School/2019/SZ/731 dated 05/04/2019, renewal under rule 37 of the Delhi Fire Service Rules 2010, is recommended.				
Accordingly DFA is put up for approval and signature please.				
<p><i>14/05/2022</i></p> <p>Signature of the Inspecting Officer  Name: Sh. Rajesh Kumar  Design: ADO (BCP)</p>				

DO (SD) - on on best Fit.

Dy C/O/S2  
*[Signature]*  
S/T

A.D.O (BCP)

As approved, F.T. letter is put up for your signature pl

*14/05/2022*

Dy C/O/S2  
*[Signature]*

M.S. cell