

E-23

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**


No F 6/DFS/MS/2022/School/WZ/391

Dated: 06/04/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **M. C. Primary Boys School, Sector-24/Ind, Rohini, Delhi-85**, comprised of **Ground + 01 upper floor** owned/occupied by **M. C. Primary Boys School** was granted FSC by this department vide letter **No. F.6/DFS/MS/2019/1488 dated 19.07.2019**. The premises was re-inspected by the officer concerned of this department on **25.03.2022** in the presence of **Smt. Pushpa Rani (Head of School)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by **Director of Education letter no 3298-3398 dated 01.03.2011** and the building/ premise is fit for occupancy Group B Educational with effect from **06/04/2022** for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **06/04/2022** at New Delhi



**(Dhrampal Bhardwaj)  
Dy.Chief Fire Officer  
Tel;-01123414250**

Copy to: -

1. The Commissioner, NDMC, Sector-5, Rohini, New Delhi-110085
2. The Principal, M. C. Primary Boys School, Sector-24/Ind, Rohini, Delhi-85.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

61C  
024

**INSPECTION REPORT**

1. Name & address of the building : M. C. Primary Boys School, Sector-24/Ind, Rohini, Delhi-85.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**Ground + 01 upper floor**)
4. Details of Previous NOC : F.6/DFS/MS/2019/1488 dated 19.07.2019
5. Fire Safety directives letter No : Director of Education Cir. dated 01.03.2011
6. Date of inspection : 25.03.2022
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers  
From the building side : Smt. Pushpa Rani (Head of School)
9. Year of Construction : 1988
10. Applicant's letter No. : Online e-mail dated 24.02.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Cir dated 01.03.2011	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
<b>2.</b>	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	04	04	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5m	2m x 3 & 1.5m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.05m	MR
<b>3.</b>	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
<b>4.</b>	<b>Smoke Management System</b>			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	• Total numbers	07nos.	12nos.	MR
	• Types	ABC/CO2	ABC-12	MR
	• IS marking	ISI marked	Yes	MR
<b>6.</b>	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA

	• Hooters' Location	NA	NA	NA
8.	<b>MOEFA</b>	NA	NA	NA
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	• Basement	NA	NA	NA
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	<b>Pumping Arrangements</b>			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	<b>Exit Signage.</b>	NA	NA	NA
16.	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	<b>Standby power supply</b>	NA	NA	NA
18.	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA

N/14

Special Fire Protection System for Protection of special Risks, if any:

NA

NA

NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. F.6/DFS/MS/2019/1488 dated 19.07.2019 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

*[Handwritten Signature]*  
28/7/22

Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Rohini)

DO (NW) *[Handwritten Signature]*

*[Handwritten Signature]*  
29/3

D.O. (WEST)/117  
DATED 29/3/2022

*[Handwritten Signature]*  
DCFO (A2)

*[Handwritten Signature]*  
31/3/2022

~~ADO/Rohini~~

FT letter is for up for kind perusal and signature please.

*[Handwritten Signature]*  
DCFO (W2)

*[Handwritten Signature]*  
5/4/2022

*[Handwritten Signature]*  
11/4/22

MSI *[Handwritten Signature]*