

E14

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**


No F 6/DFS/MS/2022/School/WZ/390

Dated: 06/04/2022

FIRE SAFETY CERTIFICATE

Certified that the NDMC Primary Co-Ed School, Sector-25, Rohini, Delhi-85, comprised of 02 blocks- Gr. floor & Gr. + 01upper floor owned/occupied by NDMC Primary Co-Ed School was granted FSC by this department vide letter No. F.6/DFS/MS/School/2018/662 dated 12.04.2018. The premises was re-inspected by the officer concerned of this department on 25.03.2022 in the presence of Smt. Veena Sharma (Head of School) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from 06/04/2022 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 06/04/2022 at New Delhi


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

Copy to: -

1. The Commissioner, NDMC, Sector-5, Rohini, New Delhi-110085
2. The Principal, NDMC Primary Co-Ed School, Sector-25, Rohini, Delhi-85.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doi_tire/FIRE/Home/Fire+Safety+Acts+and+R+ules/ http://www.delhi.gov.in/wps/wcm/connect/doi_tire/FIRE/Home/Forms



N/18

INSPECTION REPORT

1. Name & address of the building : NDMC Primary Co-Ed School, Sector-25, Rohini, Delhi-85.
 2. Type of Occupancy : Educational
 3. Type of Case : Renewal (02 Blocks, Gr. floor & Gr.+ 01 upper floor)
 4. Details of Previous NOC : F.6/DFS/MS/School/2018/662 dated 12.04.2018
 5. Fire Safety directives letter No : Director of Education Cir. dated 01.03.2011
 6. Date of inspection : 25.03.2022
 7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
 8. Name and designation of officers
 From the building side : Smt. Veena Sharma (Head of School)
 9. Year of Construction : 2002
 10. Applicant's letter No. : OD. No.6271 dated 02.02.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Education Cir. dated 01.03.11	Provided at site	Remarks MR/MR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	4.5m	Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5m	1.85m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor			
	f. Door Size	1.0m	1.10m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	06nos.	06nos.	MR
	• Types	ABC/CO2	ABC-06	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA

N114

Special Fire Protection System for Protection of special Risks, if any:

NA

NA

NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. F.6/DFS/MS/School/2018/662 dated 12.04.2018 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay Kumar Sharma
28/3/22

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW) / W/O

[Signature]
29/3

DCPS (W2)

[Signature]
31/3/2022

119

28/3/2022

~~ADO Rohini~~

FT letter is put up for your personal and signature please.

DCPS (W2)

[Signature]
5/4/2022

Ajay Kumar Sharma
1/4/22

ms/alf