

C-90

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2022/School/378

Dated: 6/14/2022

**FIRE SAFETY CERTIFICATE**

Certified that the building of Nigam Pratibha Vidhalaya, Sagar Pur West -I, New Delhi - 110046 having Two Block comprised of BL-A= G+1UF & BL-B=G+2 UF only owned / occupied by Delhi Government was issued FSC vide Letter No. F6/DFS/MS/School/2015/SZ/782 Dated 15/05/2015. The premises was re inspected by the officers concerned of this department on 24/03/2022 in the presence of Ms. Manju Saklani (Principal) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B "Educational building" with effect from 06/04/2022 for a period of three years. In accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/04/2022 at New Delhi by.

(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service.

Copy to:

1. The Principal, Nigam Pratibha Vidhalaya, Sagar Pur West -I, New Delhi - 110046 . (School ID-1757169)
2. Directorate of Education Old Secretariat Delhi - 110054

**Following fire safety directives must be adhered to:-**

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

19/6  
**INSPECTION REPORT**

1. Name & address of the building: Nigam Pratibha Vidhalaya, Sagar Pur West -I, New Delhi - 110046 (School ID-1757169)
2. Type of Occupancy : Educational Two Block ( BL-A=G+1UF & BL-B=G+2UF)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2015/SZ/782 Dated 15/05/2015
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 24/03/2022
7. Name of the Inspecting Officer : Udai vir singh, ADO (DWK)
8. Name and designation of Officer  
from the building side : Ms. Manju Saklani (Principal)
9. Year of Construction : 1992 & 2010
10. Applicant's letter No. : Nil dated 14/03/2022

No. of Students=2000 No. of class rooms=36 Plot area=5500 sqm <sup>2</sup> Covered area=
---

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement as per N/1,N/2&N/3	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Approachable	5 mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 nos in each block	BL-A=3 nos & BL-B=2nos	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	150cm/additional staircase of 75cm if less than 150cm	BL-A= 2x150cm & 1x139cm BL-B=2x125cm	MR Old Case
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	1.5 m	2. m each block	MR
	e. Width Of Corridor	1m	90cm,109cm	MR
	f. Door Size			



M/7

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	14 ABC & CO <sub>2</sub>	14 Provided	MR
	• Types	ISI marked	Provided	MR
	• IS marking		Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:			
	• Size of riser/down-comer	NA	100 mm	NA
	• Number of hydrants per floor	NA	01	NA
	• Hose Box	NA	Provided	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

13	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	Provided	MR
		30Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000Ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Battery backup</li> <li>➤ Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

N/9

20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2015/SZ/782 Dated 15/05/2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
 Name *Uday Kumar Singh*  
 Designation *AD*

*AD*  
*29/3/22*  
*AD*  
*29/3/22*  
*F.A.*

*Dyefo (S2)*  
*[Signature]*

*AD (PWR)*

*Sir FA letter is put up for sign ple*

*[Signature]*  
*31/3/22*

*Dyefo/S2*  
*[Signature]*

*m.s. [Signature]*