

C-35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/EH/2022/SZ/80

Dated 06/04/2022

FIRE SAFETY CERTIFICATE

Certified that **M/s Nomimona** (A Unit of Green Light Café Private Limited) at **Unit No R-8, UGF, East Wing, Epicuria Nehru place Metro Station, New Delhi 110019 PD Area** Comprised of lower ground & upper ground floor. The restaurant is running at upper ground floor only owner /occupied by Sh. Vijay Kumar was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/EH/2019/SZ/681 dated 02/04/2019 for the name of M/s Lord of the Drinks. The restaurant premise was re-inspected by the officer concerned of this department on 30/03/2022 in the presence of Sh. Puneet Kumar of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** (Restaurant) as above with effect from 06/04/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/04/2022 at New Delhi by



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi-110016 (Ref. MHA Portal ID 2022032103883 dated 22/03/2022)
2. **M/s Nomimona** (A Unit of Green Light Café Private Limited) at Unit No- R-8, UGF, East Wing, Epicuria Nehru place Metro Station, New Delhi 110019

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

1-001/

INSPECTION REPORT

1	Name & Address of the Building	M/s Nomimona (A Unit of Green Light Café Private Limited) at Unit No R-8, UGF, East Wing, Epicuria Nehru place Metro Station, New Delhi 110019		
2	Type of Occupancy	Group-D Assembly Building. (Eating house)		
3	Building Comprised of	Lower Ground Floor & Upper Ground Floor (PD area at Nehru Place Metro Station)		
4	Type of Case	Renewal/ Name Change		
5	Details of Previous NOC	F.6/DFS/MS/EH/2019/SZ/681 dated 02/04/2019 for the name of M/s Lord of the Drinks		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2012/3424 dated 18/09/2012		
7	Date of Inspection	30/03/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Puneet Kumar		
10	Year of construction	2013		
11	Applicant letter No.	MHA Portal ID 2022032103883 dated 22/03/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC / BBL Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.	F6/DFS/MS/2019/SZ/1712 dated 03/09/2019		
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Restt. within TDI Mall	As above	MR
			As above	N/A
			As above	N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase	Provided & Maintained by TDI Mall /DMRC		
	➤ Upper floors.	NA	Restt at Upper GF	NA
	➤ Basement floor.	N/A	As above	N/A
	b) Width of Staircase	Provided & Maintained by TDI Mall /DMRC		
	➤ Upper floors	NA	Restt at Upper GF	NA
	➤ Basement floor	N/A	As above	N/A
	c) Protection of exits	Provided & Maintained by TDI Mall /DMRC		
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	Required	One	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	2m & 1.25 m fire escape	2 m (01 no) 1.25m (01 no) fire escape	MR
3	Compartmentation.	Provided & Maintained by TDI Mall /DMRC		
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.	Provided & Maintained by TDI Mall /DMRC		
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Exhaust Fans Provided	MR
5	Fire Extinguishers.			
	• Total numbers	04 Nos	06 Nos	MR
	• Types	ABC/CO ₂	ABC-04 & CO ₂ -02	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.	Provided & Maintained by TDI Mall /DMRC		
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.	Provided & Maintained by TDI Mall /DMRC		
	• Type of detectors	Required	As above	MR

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Required	As above	MR
		Required	As above	MR
		Required	As above	MR
		Required	As above	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System	Provided & Maintained by TDI Mall /DMRC		
	<ul style="list-style-type: none"> Basement Ground floor. Sprinkler above false ceiling 	N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
11	Internal Hydrants.	Provided & Maintained by TDI Mall /DMRC		
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	150 mm	Provided	MR
		01 No	Provided	MR
		01 No	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 	Provided & Maintained by TDI Mall /DMRC		
	<ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. 	2850 x 2 LPM	Provided	MR
		70 m each	Provided	MR
		02	Provided	MR
		180 x 2 LPM	Provided	MR
		70 m	Provided	MR
		2850 LPM	Provided	MR
		70 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level 	Provided & Maintained by TDI Mall /DMRC		
	<ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	N/A	As above	N/A
		N/A	As above	N/A
		N/A	As above	N/A
		N/A	As above	N/A
14	Captive water storage for fire fighting.	Provided & Maintained by TDI Mall /DMRC		
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	100,000 ltr	1,00,000 ltrs	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	20,000 ltr	MR
		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.	Provided & Maintained by TDI Mall /DMRC		
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby Power Supply	Required	Provided (DG Set)	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room.	Provided & Maintained by TDI Mall /DMRC		
	<ul style="list-style-type: none"> Detector system panel. Flow switch panel. PA system panel. Battery backup. Building floor plan. 	N/A	Provided	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	Provided	N/A

2/14

M/s Nomimona at Unit No R-8, UGF, East Wing, Epicuria Nehru place Metro Station, New Delhi 110019

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/EH/2019/SZ/681 dated 02/04/2019 for the name of M/s Lord of the Drinks, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended for **M/s Nomimona** (A Unit of Green Light Café Private Limited).

Accordingly, DFA is put up for approval and signature please.

Signature
1/14/2022

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Designation: ADO (BCP)

~~DO (SD)~~

King
01/04/22

~~DEFO(SZ)~~

F.S.

[Signature]

~~ADO (BCP)~~

As approved, F.T. letter is put up for your signature pl

1/14
5/4/2022

~~Dy CFSZ~~

[Signature]

M. S. Cell