

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/Petrol/2022/SZ/ 141

Dated: 01/04/2022

**FIRE SAFETY CERTIFICATE**

Certified that M/s **Raj Kumar Service Station (Retail outlet of Indian Oil Corporation Limited)** located at **I.I.T Crossing, Hauz Khas, Mehrauli, Road, New Delhi 110016** comprised of **Single Story Building** was issued FSC by this department vide letter No. F6/DFS/MS/Petl./2019/SZ/21 Dated 03/01/2019. The premises was re-inspected by the officer concerned of this department on 21/03/2022 in the presence of Sh. Surender Chawla of the said filling station and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group-J, Hazardous Building** as above with effect from 01/04/2022 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 01/04/2022 at New Delhi by

  
(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER (SZ)



Copy to: -

1. The Administrative Officer, South Zone, South MCD, Green Park, New Delhi-110016
2. M/s Raj Kumar Service Station (Retail outlet of Indian Oil Corporation Limited) located at I.I.T Crossing, Hauz Khas, Mehrauli, Road, New Delhi 110016.

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any deviation, with regard to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

2/24

### INSPECTION REPORT

|    |   |   |
|----|---|---|
| 1  | Name & Address of the Building                        | M/s Raj Kumar, Service Station, I.I.T Crossing Hauz Khas, Mehrauli Road, New Delhi 110016.<br>(Retail Outlet of I.O.C.L, Petroleum Class A & B) |
| 2  | Type of Occupancy                                     | Hazardous Building (Group-J)  |
| 3  | Building Comprised of                                 | Ground floor only   |
| 4  | Type of Case  | Renewal   |
| 5  | Details of Previous NOC                               | F6/DFS/MS/Petrol/2019/SZ/21 Dated 03/01/2019  |
| 6  | Fire Safety Directives Letter No                      | Nil   |
| 7  | Date of Inspection                                    | 21-03-2022  |
| 8  | Name of the Inspecting Officers                       | Sh. Rajesh Kumar ADO (BCP)  |
| 9  | Name & Designation of Officers from the building side | Sh. Surender Chawla   |
| 10 | Year of construction                                  | 1965  |
| 11 | Applicant letter No.                                  | Outdoor dairy no 7111 Dated 07-03-2022  |

| S. No | Minimum standards on Fire Prevention and Fire Safety U/R 33   | Old NOC requirements                 | Provided at Site  | Remarks MR/NMR                       |
|-------|---|--------------------------------------|---|--------------------------------------|
| 1     | <b>Access to Building.</b>  |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>  | 09 mtr<br>-NA-<br>-NA-               | 09 mtr<br>-NA-<br>-NA-                                      | MR<br>-NA-<br>-NA-                   |
| 2     | <b>Number, width, type and arrangements of exits.</b>   |                                      |   |                                      |
|       | <b>a. Number of Staircase</b>   |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Upper floors</li> <li>Basement floor</li> </ul>  | -NA-<br>-NA-                         | -NA-<br>-NA-  | -NA-<br>-NA-                         |
|       | <b>b. Width of Staircase</b>  |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Upper floors</li> <li>Basement floor</li> </ul>  | -NA-<br>-NA-                         | -NA-<br>-NA-  | -NA-<br>-NA-                         |
|       | <b>c. Protection of exits</b>   |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>   | -NA-<br>-NA-                         | -NA-<br>-NA-  | -NA-<br>-NA-                         |
|       | <b>d. No. of continuous staircase to terrace</b>  | -NA-                                 | -NA-  | -NA-                                 |
|       | <b>e. Width of corridor</b>   | -NA-                                 | -NA-  | -NA-                                 |
|       | <b>f. Door size</b>   | -NA-                                 | -NA-  | -NA-                                 |
| 3     | <b>Compartmentation.</b>  |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Fire check door.</li> <li>Sealing of electrical shafts.</li> <li>Fire rating of shaft door.</li> <li>Water curtain</li> <li>Fire dampers.</li> </ul> | -NA-<br>-NA-<br>-NA-<br>-NA-<br>-NA- | -NA-<br>-NA-<br>-NA-<br>-NA-<br>-NA-                        | -NA-<br>-NA-<br>-NA-<br>-NA-<br>-NA- |
| 4.    | <b>Smoke Management system.</b>   |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> </ul>  | -NA-<br>-NA-                         | -NA-<br>-NA-  | -NA-<br>-NA-                         |
| 5.    | <b>Fire Extinguishers.</b>  |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>   | 20 Nos<br>ABC/CO2/DCP<br>Required    | Provided<br>CO <sub>2</sub> (4.5 kg) ABC & Foam<br>Provided | MR<br>MR<br>MR                       |
| 6.    | <b>First Aid Hose Reels.</b>  |                                      |   |                                      |
|       | <ul style="list-style-type: none"> <li>Total numbers on each floor.</li> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>  | -NA-<br>-NA-<br>-NA-                 | -NA-<br>-NA-<br>-NA-  | -NA-<br>-NA-<br>-NA-                 |

|     |  |          |                            |      |
|-----|--|----------|----------------------------|------|
| 7   | <b>Automatic Fire Detection and Alarming system.</b> |          |                            |      |
|     | • Type of detectors                                  | -NA-     | -NA-                       | -NA- |
|     | • Location of Main Panel                             | -NA-     | -NA-                       | -NA- |
|     | • Location of Repeater Panel                         | -NA-     | -NA-                       | -NA- |
|     | • Alternate source of power                          | -NA-     | -NA-                       | -NA- |
|     | • Hooter's location                                  | -NA-     | -NA-                       | -NA- |
| 8.  | <b>MOEFA</b>   | -NA-     | -NA-                       | -NA- |
| 9.  | <b>Public Address System</b>                         | -NA-     | -NA-                       | -NA- |
| 10. | <b>Automatic Sprinkler System</b>                    |          |                            |      |
|     | • Basement   | -NA-     | -NA-                       | -NA- |
|     | • Upper floors                                       | -NA-     | -NA-                       | -NA- |
|     | • Sprinkler above false ceiling                      | -NA-     | -NA-                       | -NA- |
| 11. | <b>Internal Hydrants.</b>                            |          |                            |      |
|     | • Size of Riser / Down-comer                         | -NA-     | -NA-                       | -NA- |
|     | • Number of Hydrant per floor                        | -NA-     | -NA-                       | -NA- |
|     | • Hose box.  | -NA-     | -NA-                       | -NA- |
| 12. | <b>Yard Hydrants.</b>                                |          |                            |      |
|     | • Total number of hydrants.                          | -NA-     | -NA-                       | -NA- |
|     | • Hose box.  | -NA-     | -NA-                       | -NA- |
| 13. | <b>Pumping arrangements.</b>                         |          |                            |      |
|     | • <b>Ground Level</b>                                |          |                            |      |
|     | ➤ Discharge of main pump.                            | -NA-     | -NA-                       | -NA- |
|     | ➤ Head of main pump.                                 | -NA-     | -NA-                       | -NA- |
|     | ➤ Number of main pumps.                              | -NA-     | -NA-                       | -NA- |
|     | ➤ Jockey Pump output.                                | -NA-     | -NA-                       | -NA- |
|     | ➤ Jockey Pump head.                                  | -NA-     | -NA-                       | -NA- |
|     | ➤ Standby Pump output.                               | -NA-     | -NA-                       | -NA- |
|     | ➤ Standby Pump head.                                 | -NA-     | -NA-                       | -NA- |
|     | ➤ Auto Starting/Manual Stopping.                     | -NA-     | -NA-                       | -NA- |
|     | • <b>Terrace Level</b>                               |          |                            |      |
|     | ➤ Discharge of pump.                                 | -NA-     | -NA-                       | -NA- |
|     | ➤ Head of pump.                                      | -NA-     | -NA-                       | -NA- |
|     | ➤ Power supply.                                      | -NA-     | -NA-                       | -NA- |
|     | ➤ Auto starting of pump.                             | -NA-     | -NA-                       | -NA- |
| 14. | <b>Captive water storage for fire-fighting.</b>      |          |                            |      |
|     | • Underground tank capacity.                         | -NA-     | -NA-                       | -NA- |
|     | ➤ Draw-off connection.                               | -NA-     | -NA-                       | -NA- |
|     | ➤ Fire Service Inlet.                                | -NA-     | -NA-                       | -NA- |
|     | ➤ Access to tank.                                    | -NA-     | -NA-                       | -NA- |
|     | • Overhead tank capacity.                            | -NA-     | -NA-                       | -NA- |
| 15. | <b>No Smoking Signage (Hindi &amp; English)</b>      | Required | Provided (Hindi & English) | MR   |
| 16. | <b>Provision of Lifts. -</b>                         |          |                            |      |
|     | • Pressurization of lift shaft.                      | -NA-     | -NA-                       | -NA- |
|     | • Pressurization of lift lobby.                      | -NA-     | -NA-                       | -NA- |
|     | • Communication in lift car.                         | -NA-     | -NA-                       | -NA- |
|     | • Fireman's switch.                                  | -NA-     | -NA-                       | -NA- |
|     | • Lift signage.                                      | -NA-     | -NA-                       | -NA- |
| 17  | <b>Standby Power Supply</b>                          | -NA-     | Provided (DG Set)          | -NA- |
| 18. | <b>Refuge Area</b>                                   |          |                            |      |
|     | • Total area   | -NA-     | -NA-                       | -NA- |
|     | • Location   | -NA-     | -NA-                       | -NA- |

N/28

|     |   |      |      |      |
|-----|---|------|------|------|
| 19. | <b>Fire Control Room.</b>   |      |      |      |
|     | • Detector System Panel.  | -NA- | -NA- | -NA- |
|     | • Flow Switch Panel.  | -NA- | -NA- | -NA- |
|     | • PA system Panel.  | -NA- | -NA- | -NA- |
|     | • Battery backup  | -NA- | -NA- | -NA- |
|     | • Building floor plan   | -NA- | -NA- | -NA- |
| 20. | <b>Special Fire Protection System for the Protection of special Risk, if any.</b> | NA   | NA   | MR   |

The fire protection system such as fire extinguisher of different type and capacity, Fire buckets filled with loose dry sand & water provided at suitable places in the retail outlet area were checked and found functional at the time of inspection. "No Smoking" sign board were found displayed both Hindi & English at conspicuous places. No loose electrical wiring was seen in the premises.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under rules, renewal of the FSC issued vide letter No. F6/DFS/MS/Petl./2019/SZ/21 Dated 03/01/2019, under rules 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.



Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Designation: ADO(BCP)

~~DO (SD)~~

Ring  
23/03/20


F.T.

DEFO(SZ)  
 

ADO(BCP)

As approved, F.T. letter is forward for your signature P1

104  
28/3

Dy CFO(SZ)  


M.S. (CP)