

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI**


No. F6/DFS/MS/MN/Metro/2022 /143

Dated: 01/04/2022

FIRE SAFETY CERTIFICATE

Certified that the **Rajouri Garden Metro Station (Line No. -03)** Located at **Rajouri Garden Metro Station (Line No. -03) New Delhi**, comprised of **Basement + Ground + Concourse & Platform (Except PD Area)**, was issued FSC vide Letter No. **F6/DFS/MS/2019/WZ/34 dated 07/01/2019**. The premises was re inspected by the officer concerned of this department on 21/03/2022 in the presence of **Sh. Pushkar Singh (AM/Fire)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D sub Division D- with effect from 01/04/22 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 01/04/2022 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. Sh. Vivek Srivastava (JGM/E&M), Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations/ Addition & Alteration w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per BBL-1983.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. All Exits & Passage lead to ground should be kept from any obstruction.

INSPECTION REPORT

1. Name & address of the building : Rajouri Garden Metro Station Line No. 03 (Except PD area)
Located at Rajouri Garden, New Delhi-110026
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Basement + Ground + Concourse + Platform)
4. Details of previous NOC : F6/DFS/MS/2017/29 dated 06/01/2017
5. Fire Safety directives letter No : NIL
6. Date of inspection : 21/03/2022
7. Name of the Inspecting Officers : Sarabjeet Singh (ADO MN)
8. Name and designation of officers
from the building side : Sh. Pushkar Singh (AM/Fire)
9. Year of Construction : 2005 (As per prev. Insp. report 21/12/2018)
10. Applicant's letter No. : E-Mail dated - 03/09/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement/ As per prev. Insp. report 21/12/2018	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	On Main Road	Provided	MR
	• Gate width	05 mts	On Main Road	MR
	• Width of internal road	NA	NA	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases			
	• Upper Floors	2m	G to LC=2x4.1m(P-1) & 4.1m, 4.2m (P-2) LC to UC=4m,4.1m P-1 & 4.65m, 4.7m (P-2) UC to P=4x4.1m (2 for each platform)	MR(Old Case)
	• Basements	Required	Provided	MR(Old Case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
		NA	NA	NA
	e. No. of continuous staircases to terrace	Old Case	Provided	MR
	f. Width of Corridor	2 m	Provided	MR
	g. Door Size			
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	NA	NA	NA



5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	35 nos. CO2 & WCO2, ISI Required	Provided	MR
			Provided	MR
			Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	2 (At Each PF)	Provided	MR
		30 m	Provided	MR
		05 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8	MOEFA	Smoke	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm	Provided	MR
		02 on each P.F.	Provided	MR
		Required	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	02	Provided	MR
		Required	Provided	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	All the pumps are connected are generator also		
		1800 lpm	Provided	MR
		60m	Provided	MR
		01	Provided	MR
		180 lpm	Provided	MR
		60 m	Provided	MR
		1800 lpm	Provided	MR
		60m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	50,000 ltrs	Provided	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	NA	10,000 ltrs Provided	NA
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> Communication In lift Car 	Required	Provided	MR
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	Required	Provided	MR
	<ul style="list-style-type: none"> Lift Signage 	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Location 	NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> PA System Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Batter backup 	Required	Provided	MR
	<ul style="list-style-type: none"> Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	Co2 Flooding for ASS, HT,LT Pannel	Provided	MR

The fire protection systems provided in the Building were test checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of fire safety certificate is issued vide letter no. F6/ DFS/ MS/2019/WZ/34 dated 17/01/2019 is recommended.

77/ADO/4W
21/03/22
Do (west)

[Signature]
21/03/2022

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

D.O. (WEST) 127
DATE: 28/03/22

[Signature]
21/03/2022
DO (WZ)

ADO (MN)

Sir, F.T is put up for your personal e signature. please.

[Signature]
31/3/2022

[Signature]
28/4/22

[Signature]