

C 14

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F6/DFS/MS/School/2022/NDZ/397

Dated: 07/04/2022

FIRE SAFETY CERTIFICATE

Certified that the Saraswati Bal Bharti Public School, located at E-5/163, St. No.-3,5th Pusta, Sonia vihar, Delhi-94, comprised of ground plus one upper floor owned/occupied by Saraswati Bal Bharti Public School was issued FSC vide letter No. F.6/DFS/MS/School/2017/NDZ/365 dated 06/03/2018. The school building was re-inspected by the officer concerned of this department on 04/04/22 in presence of Mr. Ajay Kumar (Head Master) of the school and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with circular No. 262-362 dated 17/01/2005 issued by Director of Education and observed that school building is fit for ground plus one upper floor occupancy class "B" 'Educational Building' with effect from 07/04/2022 for a period of **three** years, subject to conditions, printed below.

Issued on.....07/04/2022..... at New Delhi by


**(Sunil Choudhary)
Dy. Chief Fire Officer**

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

To,

The Head Master,
Saraswati Bal Bharti Public School, located at E-5/163, St. No.-3,5th Pusta, Sonia vihar,
Delhi-94

Copy:-

The Dy. Director of Education,
B-Block, Yamuna Vihar, Delhi-110053

N/S

1. Name & address of the building : Saraswati Bal Bharti Public School,
E-5/163, St. No.-3,5th Pusta, Sonia vihar, Delhi-94.
2. Building is comprised of : Ground plus first floor only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2017/NDZ/365 Dt-06/03/2018
6. Fire Safety direction letter No : Dir. of Edu. Circular Letter No.262-362 Dt-17/01/05
7. Date of Inspection : 04/04/2022
8. Name of the Inspecting officer : ADO Mehmood
9. Name and designation of officer
from the building side : Mr. Ajay Kumar(Head Master)
10. Year of Construction : 2004 & 2008(Amendment)
11. Applicant's letter No : Email, Dated- 23/03/2022

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	06 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 Nos.	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 mtr.	1.35mtr & 0.97mtr	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 Nos.	01 Nos.	MR
	e. Width of Corridor	1.50 mtr.	1.50mtr	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	04 nos.	05 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

01

06	First-Aid-Hose Reels.			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump house access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the circular No. 262-362 dated 17/01/2005, it is recommended to renew Fire Safety Certificate under rule 35 of Delhi Fire Service rule 2010.

Mehmood
4/4/22

Signature of the Inspecting Officer
Name - Mehmood
Designation - A.D.O(T.P)

DO(ED)

Mehmood
4/4/22

By CEO (W.D.2) F.F.

[Signature]

A.D.O(T.P)

Sr. A.D.O. letter put up for signature please

By CEO (W.D.2)

Mehmood
7/4/22
A.D.O(T.P)