

C/16

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No.F.6 DFS/MS/School/2022/SZ/ 407

Dated: 11 / 04 / 2022

**FIRE SAFETY CERTIFICATE**

Certified that **Sardar Patel Vidya Niketan**, located at **Mandi Village, New Delhi 110047** comprised of 03 Blocks, Ground plus one upper floor and 01 Block, Ground Floor only owned occupied by Sardar Patel Vidya Niketan was issued Fire Safety Certificate by this department vide letter No. F6/MS/DFS/School/2018/SZ/2247 Dated 05/10/2018. The said premise was re-inspected by officer concerned of this department on 02/04/2022 in presence of Mrs. Sangeeta Sharma (HOS) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 11 / 04 / 2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 11 / 04 2022 at New Delhi by

  
(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, Sardar Patel Vidya Niketan, at Mandi Village, New Delhi 110047
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT				
1	Name & Address of the Building	Sardar Patel Vidya Niketan, Mandi Village, New Delhi 110047		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	03 Blocks ,Ground plus one upper floors & 01 Block-Ground floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/School/2018/SZ/2247 Dated 05/10/2018		
6	Fire Safety Directives Letter No	DOE Circular 01/03/2011		
7	Date of Inspection	02/04/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Sangeeta Sharma (HOS)		
10	Year of construction	1973		
11	Applicant letter No.	Gmail of dated 25/03/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1.	<b>Access to Building.</b>			
	• Road width	6 mtr	9 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	02 Nos	02 Nos each block	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.50m /0.75m	1.20 mtr each	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	-NA-	-NA-	-NA-
	<b>e) Width of corridor</b>	1.50 m	Provided	MR
	<b>f) Door size</b>	1 m	Provided	MR
3.	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management system.</b>			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	16 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	-NA-	01 no in two block	-NA-
	• Length of hose-reel hose.	-NA-	30m	-NA-
	• Nozzle Diameter	-NA-	5mm	-NA-
7.	<b>Automatic fire detection &amp; alarming system.</b>			





20/11

<ul style="list-style-type: none"> <li>• Flow switch panel.</li> <li>• PA system panel.</li> <li>• Battery backup.</li> <li>• Building floor plan.</li> </ul>			
	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>		

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/MS/DFS/School/2018/SZ/2247 Dated 05/10/2018, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

DO (SD) on 17/Rest

Defect

F.P.

ADO (B/A)

As approved, f.p. letter is put up for your signature P1

1/14  
8/4/2022

24/10/22

M.S. call