

246

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/EH/SZ/2022/ 77

Dated: 05/04/2022

FIRE SAFETY CERTIFICATE

Certified that the **M/s. Social Affaire Restro Bar** located at **17A/12, Gurudwara Road, Karol Bagh, New Delhi- 110005** is running on the ground floor of a building comprised of basement, ground plus three upper floors was granted FSC by this department vide letter No. F6/DFS/MS/EH/SZ/2018/1923 dated 21.08.2018. The premises was re-inspected by the officers concerned of this department on 30.03.2022 in presence of Sh. Rajat Deep, Owner/Occupier of the restaurant & Bar and found that owner/occupier have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly (Restaurant)** with effect from 05/04/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 05/04/2022 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Following Fire Safety Directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s. Social Affaire Restro Bar, 17A/12, Ground Floor, Gurudwara Road, Karol Bagh, New Delhi- 110005
2. Type of Occupancy : Assembly (Restaurant)
3. Building Composition : Restaurant is running at Ground Floor of a building comprised of basement, ground plus three upper floors.
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/EH/SZ/2018/2034 dated 05.09.2018
6. Fire Safety directives letter No : N/A.
7. Date of inspection : 30.03.2022
8. Name of the Inspecting Officers : Vedpal Chhikara, DO (SW) & P.V. Rathee, ADO (SRD)
9. Name and designation of officers from the building side : Sh. Rajat Deep (Owner/Occupier)
9. Year of Construction : Before 1994
10. Applicant's letter No. : Online application ID 2022030603156 dated 14.03.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety requirements as per FSC dt. 05.09.2018	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mts 4.5 mts N/A	Provided Directly accessible N/A	MR MR N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	<ul style="list-style-type: none"> • Upper Floors • Basements 	N/A N/A	Restaurant/Bar at GF N/A	N/A N/A
	b. Width of staircases	-	-	-
	<ul style="list-style-type: none"> • Upper Floors • Basements 	N/A N/A	N/A N/A	N/A N/A
	c. Protection of exits	-	-	-
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	e. No. of continuous staircases to terrace	--	01	---
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	02 mts	2.0 mts, 1.0 mts	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A Sealed N/A N/A N/A	N/A ---- N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	Exhaust fan provided Natural ventilation	MR MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	08 CO ₂ , ABC type ISI marked	Provided Provided Provided	MR MR MR



16	6	First-Aid Hose Reels.			
		• Total numbers on each floor	01	Provided	MR
		• Length of hose reel hose	30 m	Provided	MR
		• Nozzle diameter	5 mm	Provided	MR
17	7	Automatic fire detection and alarming system.			
18		• Type of detectors	N/A	N/A	N/A
		• Location of Main Panel	N/A	N/A	N/A
		• Location of Repeater Panel	N/A	N/A	N/A
		• Alternate source of power	N/A	N/A	N/A
		• Hooters' Location	N/A	N/A	N/A
	8	MOEFA	Required	Provided	MR
19	9	Public Address System.	N/A	N/A	N/A
	10	Automatic Sprinkler System.			
		• Basement	Required	Provided	MR
		• Upper floors	N/A	N/A	N/A
		• Sprinkler above false ceiling	N/A	N/A	N/A
20	11	Internal Hydrants			
		• Size of riser/down-comer	Required	Provided	MR
		• Number of hydrants per floor	01	Provided	MR
		• Hose Box	01	Provided	MR
	12	Yard Hydrants.			
		• Total number of hydrants	N/A	N/A	N/A
		• Hose Box	N/A	N/A	N/A
sa	13	Pumping Arrangements.			
		• Ground Level	---	---	---
		➤ Discharge of main Pump	N/A	N/A	N/A
		➤ Head of Main pump	N/A	N/A	N/A
		➤ Number of main pumps	N/A	N/A	N/A
		➤ Jockey Pump out put	N/A	N/A	N/A
		➤ Jockey pump head	N/A	N/A	N/A
		➤ Standby Pump out put	N/A	N/A	N/A
		➤ Standby Pump Head	N/A	N/A	N/A
		➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
		➤ Pump House Access	N/A	N/A	N/A
		• Terrace level	-----	-----	-----
		➤ Discharge of pump	450 LPM	Provided	MR
		➤ Head of the pump	30 mts	Provided	MR
		➤ Power Supply	Required	Provided	MR
		➤ Auto Starting of pump	Required	Provided	MR
	14	Captive Water Storage for fire fighting.			
		• Underground tank capacity	N/A	N/A	N/A
		➤ Draw-off connection	N/A	N/A	N/A
		➤ Fire service inlet	N/A	N/A	N/A
		➤ Access to tank	N/A	N/A	N/A
		• Overhead Tank capacity	20,000 lts	Provided	MR
	15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided (125 KVA)	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Two ABC type fire extinguisher found provided near elect. panel	MR

The fire protection systems provided in the building were test checked at random and found satisfactory at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/EH/SZ/2018/2034 dated 05.09.2018, renewal under Rule 37 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

[Handwritten Signature]

Signature of the Inspecting Officer
Name- Vedpal Chhikara
Divisional Officer (SW)

[Handwritten Signature] 20/10/22

Signature of the Inspecting Officer
Name- P.V. Rathee
Asstt. Div. Officer (S.Rd)

[Handwritten Signatures]
Dy. C.O. (S2)
ADD (S.Rd)
F.T.