

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2022/SZ/ 375

Dated: 06 / 04 / 2022

FIRE SAFETY CERTIFICATE

Certified that the **S.D.M.C Primary School, (Girls/Boys)** located at **Giri Nagar, Kalkaji, New Delhi -110019** comprised of Ground plus Two upper floor owned / occupied by SDMC of Delhi was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2019/SZ/728 dated 05/04/2019. The said premises was re-inspected by officer concerned of this department on 26/03/2022 in presence of Mrs. Meenakshi (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 06 / 04 / 2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 06 / 04 / 2022 at New Delhi by


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, S.D.M.C Primary School, (Girls/Boys) located at Giri Nagar, Kalkaji, New Delhi -110019
2. The Director of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/18

INSPECTION REPORT

1. Name & address of the building : S.D.M.C. Primary School, Girls/Boys Giri Nagar-II,
Kalkaji, New Delhi 110019
2. Type of Occupancy : Educational (School) [Ground + 2 Upper floor]
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/School/2019/SZ/728 dated 05/04/2019
5. Fire Safety directives letter No : DOE circular Dated 01/03/2011
6. Date of inspection : 26/03/2019
7. Name of Inspecting Officer : Sh. Rajesh Kumar, (BCP)
8. Name and designation of officers from the building site : Mrs. Meenakshi (Principal)
9. Year of Construction : 2006
10. Applicant's letter No. : Outdoor Diary no 6920 dated 28/02/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per old NOC	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtr NA NA	6 mtr 4.5m NA	MR NA NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Two	Two	MR
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50m / 0.75m NA	1.36m + 1.35m NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	01 Nos	Provided	MR
	e. Width of Corridor	1.50 mtr	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH 12 ACPH	NA NA	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	8 No's ISI marked	09 Nos ABC-07 Nos CO ₂ -02 Nos	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel 	NA NA	NA NA	NA NA

N/19

	<ul style="list-style-type: none"> • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement 	NA	NA	NA
	<ul style="list-style-type: none"> • Ground Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pump House Access 	450 LPM	450 LPM	MR
	<ul style="list-style-type: none"> • Terrace level 	40m	40m	MR
	<ul style="list-style-type: none"> ➤ Discharge of pump 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Power Supply 			
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 			
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw-off connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> • Overhead Tank capacity 	10,000 Lts	10,000 Lts	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> • Communication In lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> • Lift Signage 	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Location 	NA	NA	NA

N/20

19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2019/SZ/728 dated 05/04/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

[Handwritten signature]
29/3

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

~~DO (SD)~~

[Handwritten signature]
29/03/22

DeFO (SZ)

F.T.

[Handwritten signature]

ADO (BCP)

Area pertains to ADO (BCP)

[Handwritten signature]
04/4/22

ADO (BCP)

As approved, F.T. letter is put up for your signature PS

[Handwritten signature]
4/5

Dy. Insp. *[Handwritten signature]*

M.S. *[Handwritten signature]*