

265

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/2022/WZ/college&amp;inst/04

Dated: 13/04/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Delhi School of Professional Studies & Research, 9, Instructional Area, Sector-25, Rohini, Delhi-110085**, comprised of **Basement + Ground floor + 03 upper floor** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2018/1390** dated : **14.06.2018**. The premises was re-inspected by the officer concerned of this department on **24.03.2022** in the presence of **Dr. G.S. Poplis (Director)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy "**Group B Educational**" with effect from 13/04/2022 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...13/04/2022 at New Delhi by

(Dhrampal Bhardwaj)  
 Dy.Chief Fire Officer  
 Tel:-01123414250

all  
 ok

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Chairman, Delhi School of Professional Studies & Research, 9, Instructional Area, Sector-25, Rohini, Delhi-110085.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building : Delhi School of Professional Studies & Research, 9, Instructional Area, Sector-25 Rohini, Delhi-110085.
2. Type of Occupancy : Educational (**Basement + Ground + 03 upper floors**)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2018/1390 dated : 14.06.2018
5. Fire Safety directives letter No : F 6/DFS/MS/BP/2015/113 dated 15.04.2015.
6. Date of inspection : 24.03.2022
7. Name of the Inspecting Officers : A.K.Sharma ADO (Rohini)
8. Name and designation of officers from the building side : Dr. G.S. Poplis (Director)
9. Year of Construction : 2004/2017
10. Applicant's letter No. : Online e-mail dated 17.03.2022

	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/ NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	9m	MR
	• Gate width	6m	6m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	03	03	MR
	• Basements	03	03	MR
	b. Width of staircases			
	• Upper Floors	1.50 m each	1.50m x 2 & 1.20m	MR
	• Basements	1.50m each	1.50m x 2 & 1.20m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA

N/29

	<ul style="list-style-type: none"> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour	Exhaust fan	MR
		12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>	28nos	30 nos	MR
		ABC & Co2	30-ABC	MR
		Yes	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01	Provided	MR
		30m	30m	MR
		5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	100mm	NA
		NA	01	NA
		NA	01	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	01Nos	NA
		NA	01Nos	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> </ul> </li> </ul>			
		1620 lpm	1620 lpm	MR
		60 M	60 M	MR

	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level               <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	02	02	MR
		180 LPM	180 LPM	MR
		60 M	60 M	MR
		1620 lpm	1620 lpm	MR
		60 M	60 M	MR
		Required	Provided	MR
		900 lpm	900 lpm	MR
		30m	30m	MR
		Required	Provided	MR
		Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	50000 ltr.	50000 ltr.	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		15,000 ltr	20,000 ltr.	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided DG Set	MR
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>	Required	Provided	MR

N/31

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 22 dated 31.08.2021, the FSC issued vide letter no. F.6/DFS/MS/2018/1390 dated: 14.06.2018, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

*[Handwritten signature]*  
13/8/22

Signature of the Inspecting Officer

Name Ajay Kumar Sharma

Designation ADO(Rohini)

~~DO (NW)~~

*[Handwritten signature]*  
05/04/2022  
~~By cfo (w2)~~  
*[Handwritten signature]*  
18/4/2022

~~ADO Rohini~~

FT letter is put up for kind  
perusal and signature please

~~DCFO (w2)~~

*[Handwritten signature]*  
18/4/2022

*[Handwritten signature]*  
11/4/22

MS/ all