

C-6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/EH/SZ/2022/90

Dated..13/4../2022

FIRE SAFETY CERTIFICATE

Certified that **M/s EFFINGUT, (A Unit of Effingut Breweries Pvt Ltd)** located at **Shop No 10, Ground Floor, Shop No 2, 3, 4, 5, 6, 7, 9 & 9 (A) on First Floor, MGF Metropolitan Mall, Saket, New Delhi-110023** in the building comprised of 02 tiers Basement, Ground plus Seven upper Floors owned/occupied by Mr. Manish Tandan (owner) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 02/04/2022 in the presence of Mr. K. K Jain and that the premise is fit for occupancy class **Group-D Assembly Building (Restaurant at Ground and First Floor)** with effect from 13 / 4 / 2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 13 / 4 / 2022 at New Delhi by


(ATUL GARG)
DIRECTOR / DFS

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi- 110016 (Ref. MHA Portal ID 2022010500242 dated 08/03/2022)
2. M/s EFFINGUT, (A Unit of Effingut Breweries Pvt Ltd) located at Shop No 10, Ground Floor, Shop No 2, 3, 4, 5, 6, 7, 9 & 9 (A) on First Floor, MGF Metropolitan Mall, Saket, New Delhi- 110023

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

N/4

INSPECTION REPORT

1	Name & Address of the Building	M/s EFFINGUT, (A Unit of Effingut Breweries Pvt Ltd) located at Shop No 10, Ground Floor, Shop No 2, 3, 4, 5, 6, 7, 9 & 9 (A) on First Floor, MGF Metropolitan Mall, Saket, New Delhi-110023.		
2	Type of Occupancy	Assembly Building "Group-D" Restaurant		
3	Building Comprised of	Basement, Ground plus Seven Upper Floors, Restaurant at Ground and First floor only.		
4	Type of Case	New Case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F6/DFS/MS/2019/Mall/SZ1371 dated 02/07/2019 for MGF Metropolitan Mall, Saket New Delhi		
7	Date of Inspection	02/04/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. K. K Jain		
10	Year of construction	2007		
11	Applicant letter No.	MHA Portal ID 2022010500242 dated 08/03/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirement/ Existing Fire Protection	Provided at Site	Remarks MR/NMR
1	Access to Building. FSC- F6/DFS/MS/2019/Mall/SZ1371 dated 02/07/2019 for MGF Metropolitan Mall, Saket New Delhi			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Restaurant within Mall NA	As above As above As above	MR N/A N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Upper floors Basement floor 	N/A N/A	As above As above	N/A N/A
	b. Width of Staircase	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Upper floors Basement floor 	N/A N/A	As above As above	N/A N/A
	c. Protection of exits	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	As above As above	N/A N/A
	d. No. of continuous staircase to terrace	07 Required	As above	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2 No's Exit each 1.50 mtr	1.50 mtr & 1.50 mtr	MR
3	Compartmentation.	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	Required Required 2 hrs N/A N/A	As above As above Provided N/A N/A	MR MR MR N/A N/A
4	Smoke Management system.	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Basement Upper floors 	N/A Required	As above Exhaust fans provided	N/A MR
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	8 Nos ISI marked	08 Nos. ABC-04, W.CO ₂ -04 Provided	MR MR MR
6	First Aid Hose Reels.	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. 	Hose Reel	02 in Restaurant 30m	MR MR

N/S

	<ul style="list-style-type: none"> Nozzle Diameter 		5mm	MR
7	Automatic Fire Detection and Alarming system.	Provided & Maintained by MGF Metropolitan		
	<ul style="list-style-type: none"> Type of detectors 	Required	Smoke & Heat	MR
	<ul style="list-style-type: none"> Location of Main Panel 	Required	As above	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	Required	As above	MR
	<ul style="list-style-type: none"> Hooter's location 	Required	As above	MR
8.	MOEFA	Required	As above	MR
9.	Public Address System	Required	As above	MR
10.	Automatic Sprinkler System	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Basement 	Required	As above	MR
	<ul style="list-style-type: none"> Upper floors 	Required	Provided in Restt.	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants.	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	Required	As above	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	Required	As above	MR
	<ul style="list-style-type: none"> Hose box. 	Required	As above	MR
12.	Yard Hydrants.	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Total number of hydrants. 	N/A	As above	N/A
	<ul style="list-style-type: none"> 2. Hose box. 	N/A	As above	N/A
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	4500 LPM	As above	MR
	<ul style="list-style-type: none"> ➤ Head of main pump. 	60 mtr	As above	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	Two	As above	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	180 LPM	As above	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	60 mtr	As above	MR
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	4500 LPM	As above	MR
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	60 mtr	As above	MR
	<ul style="list-style-type: none"> ➤ Auto Starting / Manual Stopping. 	Required	As above	MR
	<ul style="list-style-type: none"> ➤ Access to pump house 	Required	As above	MR
	<ul style="list-style-type: none"> Terrace Level 	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	N/A	As above	N/A
	<ul style="list-style-type: none"> ➤ Head of pump. 	N/A	As above	N/A
	<ul style="list-style-type: none"> ➤ Power supply. 	N/A	As above	N/A
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	N/A	As above	N/A
14.	Captive water storage for Fire Fighting.	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Underground tank capacity. 	3,00,000 Ltrs	As above	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	Required	As above	MR
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	Required	As above	MR
	<ul style="list-style-type: none"> ➤ Access to tank. 	Required	As above	MR
	<ul style="list-style-type: none"> Overhead tank capacity. 	50,000 Ltrs	As above	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	Required	As above	MR
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	Required	As above	MR
	<ul style="list-style-type: none"> Communication in lift car. 	Required	As above	MR
	<ul style="list-style-type: none"> Fireman's switch. 	Required	As above	MR
	<ul style="list-style-type: none"> Lift signage. 	Required	As above	MR
17	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A

n/6

19.	Fire Control Room.	Provided & Maintained by MGF Metropolitan Mall,			
		• Detector System Panel.	Required	As above	MR
		• Flow Switch Panel.	Required	As above	MR
		• PA system Panel.	Required	As above	MR
		• Battery backup	Required	As above	MR
		• Building floor plan	Required	As above	MR
20.	Special Fire Protection System for the Protection of special Risk, if any :	Required	As above	MR	
		Required	As above	MR	

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer
Name: Rajesh Kumar
Designation: ADO / BCP

DO (SD)

on m/dest
Director
11/4/22

11/4/22
1268

11/4
1404/22

11/4/22

Director
13/04/22

Approved, F.T. letter
is put up for your signal

11/4
12/4

uploaded
11/4/22