

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6 DFS/MS/School/2022/SZ/424

Dated: 13/04/2022

**FIRE SAFETY CERTIFICATE**

Certified that Sarvodaya Kanya Vidyalaya located at Sector – 1, M.B Road Pushp Vihar, New Delhi-110017, (School ID- 1923071) comprised of Four Blocks- Ground plus one upper floor (03 Blocks) & Ground Floor Only (01 Block) owned/ occupied by Directorate of Education, Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2019/SZ/1759 Dated 12/09/2019. The said premises was re-inspected by officer concerned of this department on 02/04/2022 in presence of Mrs. Veena Devi Sejwal (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class “**Educational Building**” Group – B with effect from 13/04/2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 13/04/2022 at New Delhi by

  
(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

ok

Copy to: -

1. The Principal, Sarvodaya Kanya Vidyalaya located at Sector – 1, M.B Road Pushp Vihar, New Delhi-110017, (School ID- 1923071)
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

**Conditions for the validity of Fire Safety Certificate**


1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/ occupier shall submit a declaration every year in Form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.”

## INSPECTION REPORT

1	Name & Address of the Building	Sarvodaya Kanya Vidyalaya, Sec-01 M.B. Road, Pushp Vihar, New Delhi 110017 (ID- 1923071)		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	School has Four Blocks- Ground plus one upper floor (03 Blocks) Ground Floor (01 Block)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2019/SZ/1759 Dated 12/09/2019		
6	Fire Safety Directives Letter No	DOE dated 01/03/2011		
7	Date of Inspection	02/04/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Veena Devi Sejwal (Principal)		
10	Year of construction	2010		
11	Applicant letter No.	Outdoor diary no 7652(A) dated 28/03/2022		
S. No.	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>As per OLD NOC Requirement</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to Building.</b>			
	• Road width	06 mtr	06 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	02 Nos	A Blk- 02 Nos, B Blk- 01 No & C Blk- 02No	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.5m / 0.75m	Block A-1.80m each, Block B- 1.50m, Block-B - 1.80 m each	MR
	➤ Basement floor	-NA-	-NA-	NA
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	01 Nos	Provided 01 at each	MR
	<b>e) Width of corridor</b>	1.50 mtr	Provided	MR
	<b>f) Door size</b>	1 mtr	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5	<b>Fire Extinguishers.</b>			
	• Total numbers	24 Nos	24 Nos	MR
	• Types	ABC / CO2	CO2 & ABC	MR
	• ISI Marking	ISI marked	Provided	MR
6	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	-NA-	-NA-	-NA-
	• Length of hose-reel hose.	-NA-	-NA-	-NA-
	• Nozzle Diameter	-NA-	-NA-	-NA-
7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	-NA-	-NA-	-NA-

	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooter's location</li> </ul>	-NA-	-NA-	-NA-
8	<b>MOEFA</b>	-NA-	-NA-	-NA-
9	<b>Public Address System</b>	-NA-	-NA-	-NA-
10	<b>Automatic Sprinkler System</b>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> <li>• Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
11	<b>Internal Hydrants.</b>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Size of Riser/Down-comer</li> <li>• Number of Hydrant per floor</li> <li>• Hose box.</li> </ul>	-NA-	-NA-	-NA-
12	<b>Yard Hydrants.</b>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Total number of hydrants.</li> <li>• Hose box.</li> </ul>	-NA-	-NA-	-NA-
13	<b>Pumping arrangements.</b>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• <b>Ground Level</b> <ul style="list-style-type: none"> <li>➤ Discharge of main pump.</li> <li>➤ Head of main pump.</li> <li>➤ Number of main pumps.</li> <li>➤ Jockey Pump output.</li> <li>➤ Jockey Pump head.</li> <li>➤ Standby Pump output.</li> <li>➤ Standby Pump head.</li> <li>➤ Auto Starting/Manual Stopping.</li> <li>➤ Pump house access.</li> </ul> </li> <li>• <b>Terrace Level</b> <ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> <li>➤ Head of pump.</li> <li>➤ Power supply.</li> <li>➤ Auto starting of pump.</li> </ul> </li> </ul>	-NA-	-NA-	-NA-
14	<b>Captive water storage for fire fighting.</b>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Underground tank capacity. <ul style="list-style-type: none"> <li>➤ Draw-off connection.</li> <li>➤ Fire Service Inlet.</li> <li>➤ Access to tank.</li> </ul> </li> <li>• Overhead tank capacity.</li> </ul>	-NA-	-NA-	-NA-
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Pressurization of lift shaft.</li> <li>• Pressurization of lift lobby.</li> <li>• Communication in lift car.</li> <li>• Fireman's switch.</li> <li>• Lift signage.</li> </ul>	-NA-	-NA-	-NA-
17	<b>Standby Power Supply</b>	-NA-	-NA-	-NA-
18	<b>Refuge Area</b>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Total area</li> <li>• Location</li> </ul>	-NA-	-NA-	-NA-
19	<b>Fire Control Room.</b>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Detector system panel.</li> <li>• Flow switch panel.</li> <li>• PA system panel.</li> <li>• Battery backup.</li> <li>• Building floor plan.</li> </ul>	-NA-	-NA-	-NA-


2/20

20	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-
<p>The fire protection system provided in the building were randomly checked and found functional at the time of inspection.</p>		
<p>Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/School/2019/SZ/1759 Dated 12/09/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p>		
<p>Accordingly DFA is put up for approval and signature please.</p>		
		<p style="text-align: right;">             Signature of the Inspecting Officer            Name: Sh. Rajesh Kumar            Designation : ADO (BCP)         </p>

DO (SD) M)rest


DCFSZ

F.T.




~~ADO (BCP)~~

As approved, F.T. letter is put up for your signature pl.

  
8/4/2022

DCFSZ



M.S. UP