

C. 24

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/SZ/2022/421

Dated: 13/04/2022

FIRE SAFETY CERTIFICATE

Certified that **Shahid Captain Amit Verma Govt. S(Co-Ed), Inderpuri, New Delhi-110012**, comprised of ground plus three upper floors & A separate hall at ground floor only (newly constructed block) was inspected by the officer concerned of Delhi Fire Service on 04.04.2022 in the presence of Sh. Firtosh (Supervisor), and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Act 20007 and Rules 2010 and that the building/premises is fit for occupancy class "Educational" with effect from 13/04/2022 for a period of 03 years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed blow.

Issued on 13/04/2022 at New Delhi by.

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. The Principal, Shahid Captain Amit Verma Govt. S(Co-Ed), Inderpuri, New Delhi-110012.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
3. The Assistant Engineer (E), Sub-Div- 1 Education Division M 1 (N), PWD GNCT, Govt. of Delhi, ITI Campus, Pusa Road, New Delhi- 110012

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

INSPECTION REPORT

1. Name & address of the building : Shahid Captain Amit Verma Govt. S(Co-Ed), Inderpuri, New Delhi- 110012.
2. Type of Occupancy : Educational
3. Building Composition : Building comprised ground plus three upper floors & a separate Hall at ground floor. *(Newly Constructed Blocks)*
4. Type of Case : New Case
5. Details of previous NOC : N/A
6. Fire Safety directives letter No : N/A
7. Date of inspection : 04.04.2022
8. Name of the Inspecting Officers : P.V. Rathee, Asstt. Div. Officer (SRD)
9. Name and designation of officers
from the building side : Sh. Firtosh (Supervisor)
9. Year of Construction : 2021
10. Applicant's letter No. : 54(SPS School)/PWD Edu.Sub-Divn M1-1(N)/2021-22/8 dated 28.02.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	4.5 mts	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	03	03	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.50 mts each	1.80, 1.78 & 1.78 mts	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	c. No. of continuous staircases to terrace	03	03 Nos.	MR
	g. Width of Corridor	1.5 mts	1.80 mts	MR
	h. Door Size	1.20 mts	1.22 mts × 2 at each class room & Hall = 1.34 – 2.0 mts (total 5 nos.)	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural Ventilation	MR

16	Provision of Lifts.	Not Applicable		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked at random and found satisfactory at the time of inspection.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the Rules, it is recommended to grant fire safety certificate under Delhi Fire Service Act-2007 & Rules- 2010.

Accordingly, DFA is put up for approval & signature please.

[Handwritten Signature] 7/4/22

Signature of the Inspecting Officer
(P.V. Rathee)
Asstt. Div. Officer, (SRD)

D.O. (SW) *[Signature]*
 D.O. (SP) *[Signature]* 8/1/22
 C.F.V. (D. off.) *[Signature]* 8/1/22
 Director *[Signature]*
 11/04/2022
 Any 624