

e16

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/2022/SZ/ 433

Dated: 21/04/2022

FIRE SAFETY CERTIFICATE

Certified that the **Tirupati Public School** at 127A, Vikar Vihar, Opp. Sahib Singh Verma Stadium, Main Kakrola Road, Sector-15, Dwarka, New Delhi- 110078, Comprised of ground plus one upper floor only, owned/occupied by Tirupati Public School was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/school/2013/SZ/584 Dated- 19/07/2013. The school building was re-inspected by the officer concerned of this department on dated 04/04/2022 in the presence of Smt. Suman (Headmistress) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the building/ premises is fit for occupancy class "Educational" for a period of **three years** subject to conditions given below.

Issued on..... 21/04/2022 at New Delhi.



(Sunil Chawdhary)
Dy.Chief Fire Officer

gpc

Copy to:-

1. The Headmistress ,
Tirupati Public School, 127A, Vikar Vihar,
Opp. Sahib Singh Verma Stadium, Main
Kakrola Road, Sector-15, Dwarka, New Delhi- 110078.
2. Director of Education,
GNCT of NCT of Delhi, Old Secretariat,
Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

1/8

INSPECTION REPORT

1. Name & address of the building: Tirupati Public School at 127A, Vikar Vihar, Opp. Sahib Singh Verma Stadium, Main Kakrola Road, Sector-15, Dwarka, New Delhi- 110078.
2. Building is comprised of : **Ground plus one upper Floor**
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/school/2013/SZ/584 Dt.- 19/07/2013
6. Fire Safety direction letter No : N/A
7. Date of Inspection : 04/04/2022
8. Name of the Inspecting Officers: : ADO R.K. YADAV
9. Name of the designation of Officer from the building side : Smt. Suman (Headmistress)
10. Year of Construction : Before 2009
11. Applicant's letter No : Outdoor Diary no. 6929 Dated -28/02/2022

| S.No | Minimum Standards on fire prevention and fire safety requirements U/R 33 | Requirement | Provided at Site | Remarks MR/NMR | |
|------------------------------|--|--------------------------|---------------------|----------------|------|
| 1 | Access to building | | | | |
| | Road width | Required | 12 m | MR | |
| | Gate width | N.A. | N.A. | N.A. | |
| | Width of internal road | N.A. | N.A. | N.A. | |
| 2 | Number, Width, Type and Arrangement of Exits | | | | |
| | a. Number of Staircases | Upper Floor | Old case | 02 no. | MR |
| | | Basement | N.A. | N.A. | N.A. |
| | B. Width of Staircases | Upper Floor | N.A. | N.A. | N.A. |
| | | Basement | Old case | 1.50 & 1.15 m | MR |
| | c. Protection of exits | Fire check door | N.A. | N.A. | N.A. |
| | | Pressurization | N.A. | N.A. | N.A. |
| | e. No. of continuous staircases to terrace | 01 no. | 01 no. | MR | |
| | g. Width of Corridor | 1.50 m | 1.50 m | MR | |
| | | 1 m | 1 m | MR | |
| | 3 | Compartmentation. | | | |
| | | Fire check door | N.A. | N.A. | N.A. |
| Sealing of electrical shafts | | N.A. | N.A. | N.A. | |
| Fire rating of shaft door | | N.A. | N.A. | N.A. | |
| Water curtain | | N.A. | N.A. | N.A. | |
| Fire Dampers | | N.A. | N.A. | N.A. | |
| 4 | Smoke Management System. | | | | |
| | Basement | N.A. | N.A. | N.A. | |
| | Upper floor | Required | Natural Ventilation | MR | |


Ms

| | | | | |
|----|--|-----------------------|-----------------------|------|
| 4. | Fire Extinguisher | | | |
| | Total numbers | 07 Nos. | 07 Nos. | MR |
| | types | CO ₂ & ABC | CO ₂ & ABC | MR |
| | IS marking | ISI marked | ISI marked | MR |
| 5 | First-aid-Hose Reels. | | | |
| | Total numbers of each floor | N.A. | N.A. | N.A. |
| | Length of hose reel hose | N.A. | N.A. | N.A. |
| | Nozzle diameter | N.A. | N.A. | N.A. |
| 7 | Automatic fire detection and alarming system. | | | |
| | Type of detectors | N.A. | N.A. | N.A. |
| | Location of main panel | N.A. | N.A. | N.A. |
| | Location of repeater panel | N.A. | N.A. | N.A. |
| | Alternate source of power | N.A. | N.A. | N.A. |
| | Hooters | N.A. | N.A. | N.A. |
| 8 | MOEFA | N.A. | N.A. | N.A. |
| 9 | Public address System. | N.A. | Provided | MR |
| 10 | Automatic Sprinkler System. | | | |
| | basement | N.A. | N.A. | N.A. |
| | upper floor | N.A. | N.A. | N.A. |
| | sprinkler above false ceiling | N.A. | N.A. | N.A. |
| 11 | Internal Hydrants | | | |
| | size of riser/down-comer | N.A. | N.A. | N.A. |
| | Number of hydrants per floor | N.A. | N.A. | N.A. |
| | Hose Box | N.A. | N.A. | N.A. |
| 12 | Yard Hydrants. | | | |
| | Total number of hydrants | N.A. | N.A. | N.A. |
| | Hose Box | N.A. | N.A. | N.A. |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | N.A. | N.A. | N.A. |
| | ➤ Discharge of main Pump | N.A. | N.A. | N.A. |
| | ➤ Head of Main Pump | N.A. | N.A. | N.A. |
| | ➤ Number of main pumps | N.A. | N.A. | N.A. |
| | ➤ Jockey pump out put | N.A. | N.A. | N.A. |
| | ➤ Jockey pump head | N.A. | N.A. | N.A. |
| | ➤ Standby pump out put | N.A. | N.A. | N.A. |
| | ➤ Standby pump Head | N.A. | N.A. | N.A. |
| | ➤ Auto Starting /Manual stopping | N.A. | N.A. | N.A. |
| | ➤ Pump House Access | N.A. | N.A. | N.A. |
| | • Terrace Level | | | |
| | ➤ Discharge of pump | N.A. | N.A. | N.A. |
| | ➤ Head of the Pump | N.A. | N.A. | N.A. |
| | ➤ Power supply | N.A. | N.A. | N.A. |
| | ➤ Auto Starting of pump | N.A. | N.A. | N.A. |


| | | | | |
|-----------|---|------|------|------|
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | Underground tank capacity | N.A. | N.A. | N.A. |
| | Draw-off connection | N.A. | N.A. | N.A. |
| | Fire service inlet | N.A. | N.A. | N.A. |
| | Access to tank | N.A. | N.A. | N.A. |
| | Overhead Tank capacity | N.A. | N.A. | N.A. |
| 15 | Exit Signage. | N.A. | N.A. | N.A. |
| 16 | Provision of Lifts. | | | |
| | Pressurization of Lift Shaft | N.A. | N.A. | N.A. |
| | Pressurization of Lift lobby | N.A. | N.A. | N.A. |
| | Communication in lift car | N.A. | N.A. | N.A. |
| | Firemen's grounding switch | N.A. | N.A. | N.A. |
| | Lift Signage | N.A. | N.A. | N.A. |
| 17 | Standby power supply | N.A. | N.A. | N.A. |
| 18 | Refuge Area. | | | |
| | Total area | N.A. | N.A. | N.A. |
| | Location | N.A. | N.A. | N.A. |
| 19 | Fire Control Room | | | |
| | Detector system panel | N.A. | N.A. | N.A. |
| | Flow switch panel | N.A. | N.A. | N.A. |
| | PA system panel | N.A. | N.A. | N.A. |
| | Batter backup | N.A. | N.A. | N.A. |
| | Building Floor Plans | N.A. | N.A. | N.A. |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N.A. | N.A. | N.A. |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC was issued vide letter no. F.6/DFS/MS/school/2013/SZ/584 Dated-19/07/2013 renewal under the Rule 35 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of the Inspecting Officer
 Name R. K. YADAV
 Designation ADO (JKP)

DO (South West)


 8/11/2022
 Dy CPO (\$2)

F. 7



ADO (JKP)

F.T Letter is put up for signature please

DY CPO (\$2)



M.S. Ad


 12/11/2022