

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/EH/SZ/2022/96

Dated. 21/04/2022

FIRE SAFETY CERTIFICATE

Certified **M/s Barbeque Nation** (A Unit of Barbeque Nation Hospitality Ltd) located at Lower Ground floor, IGF Plot No 11, Sec-C, Pocket-7, LSC, Vasant Kunj, New Delhi 110070 comprised of basement, ground plus 02 Upper floor but restaurant running at ground floor only owned/occupied by A Unit of Barbeque Nation Hospitality Ltd was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2019/SZ/794 Dated 10/04/2019. The restaurant premise was re-inspected by the officer concerned of this department on 11/04/2022 in the presence of Mr. Kayum Razak of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** (Restaurant at ground floor only) as above with effect from 21/04/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/04/2022 at New Delhi by

(SUNIL CHAUDHARY)

DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi-110016 (Ref. MHA Portal 2022040105040 dated 02/04/2022)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

N/31

INSPECTION REPORT

1	Name & Address of the Building	M/s Barbeque Nation (A Unit of Barbeque Nation Hospitality Ltd) at, Shop No Lower Ground floor, IGF Plot No 11, Sec-C, Pocket-7, LSC, Vasant Kunj, New Delhi 110070		
2	Type of Occupancy	Group-D-4 Assembly (Restaurant at Ground Floor)		
3	Building Comprised of	Basement, Ground +Two upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2019/SZ/794 Dt. 10/04/2019		
6	Fire Safety Directives Letter No	F6/MS/DFS/BP/2003/2347 dated 01/10/2003		
7	Date of Inspection	11/04/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Kayum Razak		
10	Year of construction	2005		
11	Applicant letter No.	MHA Portal 2022040105040 dated 02/04/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	Road width	09 mtr	Provided	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	Upper floors.	N/A	Restt. at Ground floor	N/A
	Basement floor.	02 nos	Provided	MR
	b. Width of Staircase			
	Upper floors	NA	NA	NA
	c. Basement floor	1.50 mtr	1.25 & 1 m	MR (old case)
	d. Protection of exits			
	Fire check door	Required	Provided	MR
	e. Pressurization	N/A	N/A	N/A
	f. No. of continuous staircase to terrace	Required	01 Provided	MR
	g. Width of corridor	N/A	N/A	N/A
	h. Door size	2 m	2m, 1.4m, 1.10 & 0.80m	MR
3	Compartmentation.			
	Fire check door.	Required	Provided	MR
	Sealing of electrical shafts.	N/A	N/A	N/A
	Fire rating of shaft door.	N/A	N/A	N/A
	Water curtain	N/A	N/A	N/A
	Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	Basement	12 ACPH	N/A	N/A
	Upper floors	12 ACPH	Provided	MR
5	Fire Extinguishers.			
	Total numbers	10 Nos	10 Nos	MR
	Types	ABC/CO ₂	ABC & CO ₂	MR
	ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	Total numbers on each floor.	One	01 No Provided	MR
	Length of hose-reel hose.	30m	Provided	MR

N/30

	Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	Type of detectors	Required	Smoke type	N/A
	Location of Main Panel	Required	GF floor	N/A
	Location of Repeater Panel	N/A	N/A	N/A
	Alternate source of power	Required	Provided	N/A
	Hooter's location	Required	Provided	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	Basement	Required	Provided	MR
	Restaurant area	Required	Provided	MR
	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants.			
	Size of Riser/Down-comer	100 mm	Provided	MR
	Number of Hydrant per floor	One	Provided	MR
	Hose box.	One	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants.	Required	Provided	MR
	Hose box.	Required	Provided	MR
13	Pumping arrangements.			
	Ground Level	Fire fighting arrangements are common for the bldg		
	Discharge of main pump.	1850 LPM	Provided	MR
	Head of main pump.	60m	Provided	MR
	Number of main pumps.	01	Provided	MR
	Jockey Pump output.	180 LPM	Provided	MR
	Jockey Pump head.	60 m	Provided	MR
	Standby Pump output.	N/A	N/A	N/A
	Standby Pump head.	N/A	N/A	N/A
	Auto Starting/Manual Stopping.	Required	Provided	MR
	Pump house access.	Required	Provided	MR
	Terrace Level	Fire fighting arrangements are common for the bldg		
	Discharge of pump.	N/A	N/A	N/A
	Head of pump.	N/A	N/A	N/A
	Power supply.	N/A	N/A	N/A
	Auto starting of pump.	N/A	N/A	N/A
14	Captive water storage for fire fighting.			
	Underground tank capacity.	1,00,000 ltr	Provided	MR
	Draw-off connection.	Required	Provided	MR
	Fire Service Inlet.	Required	Provided	MR
	Access to tank.	Required	Provided	MR
	Overhead tank capacity.	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of lift shaft.	N/A	N/A	N/A
	Pressurization of lift lobby.	N/A	N/A	N/A
	Communication in lift car.	N/A	N/A	N/A
	Fireman's switch.	N/A	N/A	N/A
	Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	Total area	N/A	N/A	N/A

N/23

	Location	N/A	N/A	N/A
19	Fire Control Room.			
	Detector system panel.	N/A	N/A	N/A
	Flow switch panel.	N/A	N/A	N/A
	PA system panel.	N/A	N/A	N/A
	Battery backup.	N/A	N/A	N/A
	Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2019/SZ/794 Dt. 10/04/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

RK
21/4/2022

Signature of the Inspecting Officer
Name: - Sh. Rajesh Kumar
Designation: - ADO/BCP

~~DO (SD)~~

ADP
13/04/22

~~Dufo/SZ~~

F.T.

[Signature]

~~ADO/BCP~~

As approved, F.T. letter is put up for your signature & I

21/4
2022

~~Dufo/SZ~~
[Signature]
m.s. all