

4/12

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2022/School/454

Dated: 25/04/2022

FIRE SAFETY CERTIFICATE

Certified that the building of Deep Model School Located at Ground, 1st & 2nd Floor RZ – 260/286, Geetanjali Park, West Sagarpur, Street No. – 4, New Delhi - 110046 in a **building comprised of Basement Ground + 03 Upper Floor**, owned/occupied by M/s Deep Model School was issued FSC vide Letter No. F.6/DFS/MS/2011/1540 Dated 08/07/2011. The premises was re inspected by the officer concerned of this department on 04/04/2022 in the presence of Sh. Satish Kumar (Manager) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B “Educational building” with effect from 25/4/2022 for a period of three years. In accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/4/2022 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal Deep Model School Located at Ground 1st & 2nd Floor RZ – 260/286, Geetanjali Park, West Sagarpur, Street No. – 4, New Delhi - 110046.

Following fire safety directives must be adhered to:-

- 1 **Third Floor shall not be used for school activities.**
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 8 Basement shall be used strictly as per building bye laws.
- 9 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Deep Model School Located at RZ – 260/286, Geetanjali Park, West Sagarpur, Street No. – 4, New Delhi – 110046
2. Type of Occupancy : Educational **(At Ground + Two Upper Floors Only in a building comprised of B+G+03 Upper Floors.)**
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2011/1540 Dated 08/07/2011
5. Fire Safety directives Letter No. : NA
6. Date of inspection : 04/04/2022
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Satish Kumar (Manager)
9. Year of Construction : Before 2011 & Before 2018
10. Applicant's letter No. : DMS/FSC/2022 Dated - 21/03/2022

No. of Students=405 No. of class rooms=15 Plot area=150 sq.mtr Covered area= 150 sq.mtr
--

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/3	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	4.5 mtr (Old case)	MR
	• Gate width	NA	Directly accessible from road	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	02 Nos.	MR
	• Basements	02 Nos.	02 Nos.	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr	1.5 m & 1.30 m	MR (Old case)
	• Basements	Required	1.44 m & 1.06 m	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	150 cm	130 cm	MR (Old case)
	f. Door Size	01 mtr	01 mtr	MR (Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	12 a/c per hour	Natural ventilation	MR

N/A

16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2011/1540 Dated 08/07/2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note:- Third floor is found added in the building but school management want to run the school at Ground, 1st & 2nd Floors only. (Undertaking placed at C/9).

Signature of the Inspecting Officer
 Name *Uday Vir Singh*
 Designation *ADDTA/CP*

D. S. S. A.

M. S.
13/11/22
Dy. Insp. (S2)

M. S.

M. S. (D. W. S.)

Sir AT letter is put up for sig. file

Dy. Insp. (S2)
M. S. all

13/11/22