

9/25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2022/SZ/ 451

Dated: 25/4/2022

FIRE SAFETY CERTIFICATE

Certified that the **Fr. Peter Mermier Pre School** running at ground floor only in a building comprised of basement and ground floor located at C-1 Block, Janakpuri, New Delhi-110058, owned/occupied by Fr. Peter Mermier Pre School was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/School/2019/SZ/1128 dated 24/05/2019. The School building was re-inspected by the officer concerned of this department on 13/04/2022 in the presence of Principal and found that School have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises (**ground floor only**) is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on..... 25/4/2022 at New Delhi.



(SUNIL CHAUDHARY)
DY.CHIEF FIRE OFFICER

Copy to:-

1. The Principal,
Fr. Peter Mermier Pre School,
C-1 Block, Janakpuri, New Delhi-110058
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. In case usage of the basement for schooling purpose then FSC will be null and void.

N/10

INSPECTION REPORT

1. Name & address of the building : Fr. Peter Mermier Pre School, C-1 Block, Janakpuri, New Delhi-110058
 2. Building comprised of : Basement and ground floor but school running at ground floor only
 3. Type of Occupancy : Educational
 4. Type of Case : New
 5. Details of Previous NOC : F6/DFS/MS/School/2019/SZ/1128 dated 24/05/2019
 6. Fire Safety directives letter No : N/A
 7. Date of inspection : 13/04/2022
 8. Name of Inspecting Officer : A.D.O. R.K.Yadav
 9. Name and designation of officers
 From the building side : Principal
 10. Year of Construction : Before 2018
 11. Applicant's letter No. : Nil dated 07.04.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per Dir. of edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 mtrs N/A N/A	Provided Directly accessible from road N/A	M/R N/A N/A
2.	Number, Width, Type & Arrangement of Exits	School running at GF only		
	a. Number of staircases			GF only
	<ul style="list-style-type: none"> Upper Floors Basements 	N/A N/A	N/A N/A	N/A N/A
	b. Width of staircases			GF only
	<ul style="list-style-type: none"> Upper Floor Basements 	N/A N/A	N/A N/A	N/A N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	1.0 m	1.12m	M/R
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System	School at GF only		
	<ul style="list-style-type: none"> Basements Upper floors 	Required N/A	Provided N/A	M/R N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R

NS

N/11

6.	First-Aid Hose Reels			
	• Total numbers on each floor	N/A	Provided	M/R
	• Length of hose reel hose	N/A	Provided	M/R
	• Nozzle diameter	N/A	Provided	M/R
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	M/R
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	• Terrace level			
	➤ Pump House Access	N/A	N/A	N/A
	➤ Discharge of pump	450 LPM	Provided	M/R
	➤ Head of the pump	40 mtrs	Provided	M/R
	➤ Power Supply	Required	Provided	M/R
	➤ Auto Starting of pump	Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5000 ltrs	Provided	M/R
15.	Exit Signage.	N/A	N/A	N/A

RS

N/12

Provision of Lifts.		No Lift		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F6/DFS/MS/School/2019/SZ/1128 dated 24/05/2019 renewal under the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

Note:- As per the undertaking submitted by the Secretary (placed at C-2) the basement is not used for schooling purpose & school running at ground floor only.

R.K. Yadav

Signature of Inspecting Officer
 Name:- R.K. Yadav
 Designation:- Asstt. Divisional Officer

Divisional Officer (South West) *hbs* 20/4/22

DyCFD(S2)
F. T.

A.O.O.R.B.
E.T. hatter a put up for signature
DyCFD(S2)
 (Fr. Peter Mermier Pre School, C-1 Block, Janakpuri, New Delhi-58)
 25/4/2022