

451
452

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/2022/197

Dated : 19/4/2022

FIRE SAFETY CERTIFICATE

Certified that the **Gold Inn Guest House** located at **4653/54, Gali Ram Prashad, Shora Kothi, Pahar Ganj, New Delhi** comprises of **Ground + 04 Upper floor, Ground floor (04 Guest Rooms, Reception & Lounge), 1st floor to 3rd (07 guest rooms at each floor) & 4th floor (02 staff room + 01 store), total 25 guest rooms** owned/occupied by Gold Inn Guest House was granted FSC by this department vide letter No.F6/DFS/MS/GH/2019/NDZ/829 dated 15/04/2019. The premises was re-inspected by the officer concerned of this department on 11/04/2022 in the presence of Sh. Ashok Malhotra (Manager) and found that the said guest house building having given affidavit dated **18.12.2019 regarding not to use any floor above third floor**, deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential Group A-1 as above 25 guest rooms only** with effect from 19/4/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/4/2022 at New Delhi by.



(Dr. S. K. Tomar)
Dy. Chief Fire officer
Delhi Fire Service

Copy to:-

1. The Commissioner, North MCD, Civic Centre, New Delhi: to ensure the occupancy as detailed above.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi ID no. 2022033004596 dated 30.03.22.
3. Sh. Sarfraz Aalam (Manager),
M/S Gold Inn Guest House located at 4653/54, Gali Ram Prashad, Shora Kothi, Pahar Ganj, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1. Name & address of the building Gold Inn Guest House located at 4653/54, Gali Ram Prashad, Shora Kothi, Pahar Ganj, New Delhi
2. Type of occupancy:- Residential, Sub Division-A-1
Gr. + 04 Upper floors (total 25 Guest rooms)
Ground floor 04 Guest Rooms, Reception & Lounge
1st floor to 3rd (07 guest rooms at each floor)
4th floor (02 staff room + 01 store) not in use as per affidavit dated 18.12.2019
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/GH/2019/NDZ/829 dated 15/04/2019.
5. Fire safety directives No.- N/A
6. Date of inspection:- 12/04/22
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
Sh. Rajinder Atwal (DO/CD)
8. Name & designation of officer
From the building side:- Sh. Ashok Mahalotra (Manager)
9. Year of construction:- 2007
10. Applicant's letter No:- ID no. 20220330045496 dated 30.03.22

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	02 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 Nos.	01 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	80cm.	125 cm.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural /exhaust Ventilation	MR
5.	Fire Extinguishers			

✓

	1) Total numbers	8 Nos.	8 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	Provided	MR
	2) Length of hose reel hose	30 mtr.	Provided	MR
	3) Nozzle diameter	05 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors CO	Required	Provided	MR
	2) Location of main panel	Required	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	Ground level	N/A	N/A	N/A
	Discharge of main pump	N/A	N/A	N/A
	Head of main pump	N/A	N/A	N/A
	Number of main pump	N/A	N/A	N/A
	Jockey pump output	N/A	N/A	N/A
	Jockey pump head	N/A	N/A	N/A
	Stand by pump output	N/A	N/A	N/A
	Stand by pump head	N/A	N/A	N/A
	Auto starting/Manual stopping	N/A	N/A	N/A
	Terrace level			
	Discharge of pump	225 LPM	225 LPM	MR
	Head of pump	30 mtr.	30 mtr.	MR
	Power supply	Required	Provided	MR
	Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	Under ground tank capacity	N/A	N/A	N/A
	Draw-off connection	N/A	N/A	N/A
	Fire service inlet	N/A	N/A	N/A

N/22

	Access to tank	N/A	N/A	N/A
	Over head tank capacity	2500 ltr.	2500 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of lift shaft	N/A	N/A	N/A
	Pressurization of lift lobby	N/A	N/A	N/A
	Communication in lift car	N/A	N/A	N/A
	Fireman's switch	N/A	N/A	N/A
	Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	Detector system panel	N/A	N/A	N/A
	Flow switch panel	N/A	N/A	N/A
	PA system panel	N/A	N/A	N/A
	Battery backup	N/A	N/A	N/A
	Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/GH/2019/NDZ/829 dated 15/04/2019 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended up to third floor only.

Signature of the inspecting officer

[Signature] 12/4/22

Name: - Rajinder Atwal

Designation: - DO (CD)

Signature of the Inspecting Officer

[Signature] 12/4/22

Name: Ravinder Singh

Designation: ADO (CC)

46
13-4-22
18-4-22

[Signature] (no 2)
[Signature] 13/4/22

[Signature] As approved FT is part of forklift
used and signage of fire

[Signature]
[Signature] 18/4/22

[Signature]
18/4/22

ms