

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2022/NDZI 439

Dated: 22/04/2022

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Kanya Vidyalaya at Gokal Puri, Delhi-110094 comprised of ground plus one upper floor (separate block) owned/occupied by Govt. Sarvodaya Kanya Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with Dir. Of Education circular dated 01/03/2011 and verified by the officer concerned of Fire Service on 11/04/2022 in presence of Mr. Sanjeev Kumar (Principal) and that the school building is fit for occupancy class 'Educational Building' (Group-B) with effect from 22/04/2022 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions, printed overleaf.

Note:- This Fire Safety Certificate does not cover the ground plus three upper floor building block for which shortcomings were issued earlier vide letter No. F6/DFS/MS /School/2014/2838 dated 12/12/14.

Issued on.....22/04/2022.....at New Delhi by


(Atul Garg)
Director/DFS


To,
The Principal,
Govt. Sarvodaya Kanya Vidyalaya,
Gokalpuri, Delhi-110094.

Copy:-
The Dy. Director of Education,
B- Block, Yamuna Vihar,
Delhi-110053

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

No. F6/D

C

se

W

Y

C

- 4/9
1. Name & address of the building : Govt. Sarvodya Kanya Vidyalaya,
Gokal Puri, Delhi-110094.
 1. Building is comprised of : Ground plus one floor (Separate block)
 2. Type of Occupancy : Educational
 3. Type of Case : New
 2. Details of Previous NOC letter : Nil
 4. Fire Safety directive letter No. : Circular date 01/03/11 issued by DoE
 5. Date of Inspection : 11/04/2022
 6. Name of the Inspecting officers : ADO Mehmood
 7. Name and designation of Officer
from the building side : Mr. Sanjeev Kumar (Principal)
 8. Year of Construction : 1988-89
 9. Applicant's letter No : Email dated: 31/03/2022

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	07 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	01 nos.	02 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	1.50 mtr	1.90 mtr & 1.50 mtr.	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	1.50 mtr.	1.50 mtr.	MR
	f. Door Size	1.0 mtr.	1.0 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	06 nos.	07 nos	MR
	• Types	ABC /CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR

4/9

[Signature]

N/10

06	First-Aid-Hose Reels			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump in each Block	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A

221

221

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the circular No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by Director of Education, it is recommended to issue Fire Safety Certificate under the rule 35 of Delhi Fire Service Rules 2010 .

Mehmood
11/3/22

Signature of the Inspecting Officer
Name :- Mehmood
Designation :- A.D.O (T.Pur)

DO (ED) *[Signature]*
12/04/2022

By *[Signature]* (N.D.Z)


New case for (G+1) separate block

[Signature]
12/11/22

CFO (HD) - D/OB

Director *[Signature]*
19/04/22

DO (ED) *[Signature]*
12/14/2022
ADDY/T.P.



[Handwritten initials]