

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No F 6/DFS/MS/2022/School/WZ/ 435

Dated: 21/04/2022

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls/Boys Sr. Sec. School, D-Block, Sultanpuri, Delhi-86, comprised of 02 Blocks, Gr. floor & Gr. + 01 upper floor owned/occupied by Govt. Girls/Boys Sr. Sec. School was granted FSC by this department vide letter No. F.6/DFS/MS/2017/School/WZ/491 dated 31.03.2017. The premises was re-inspected by the officer concerned of this department on 06.04.2022 in the presence of Smt. Mamta Meena (Head of School) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from21.04.2022 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on21.04.2022.... at New Delhi

(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Govt. Girls/Boys Sr. Sec. School, D-Block, Sultanpuri, Delhi-86.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

o/c
21/4/2022

INSPECTION REPORT

1. Name & address of the building : Govt. Girls/Boys Sr. Sec. School, D-Block, Sultanpuri, Delhi-86.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (02 blocks, Gr. floor & Gr. + 01 upper floor)
4. Details of Previous NOC : F.6/DFS/MS/2017/School/WZ/491 dated 31.03.2017.
5. Fire Safety directives letter No : Director of Education Cir. dated 01.03.2011
6. Date of inspection : 06.04.2022
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Smt. Mamta Meena (Head of School)
9. Year of Construction : 1998 & 2011
10. Applicant's letter No. : Online e-mail dated 01.04.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Education Cir. dated 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Accessible 4.5m NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<ul style="list-style-type: none"> 01 NA 	<ul style="list-style-type: none"> 01 NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<ul style="list-style-type: none"> 1.5m NA 	<ul style="list-style-type: none"> 1.5m NA 	<ul style="list-style-type: none"> MR NA
	c. Protection of exits			
	Fire check door			
	<ul style="list-style-type: none"> • Pressurization 	<ul style="list-style-type: none"> NA 	<ul style="list-style-type: none"> NA 	<ul style="list-style-type: none"> NA
	d. No. of continuous staircases to terrace	<ul style="list-style-type: none"> NA 	<ul style="list-style-type: none"> NA 	<ul style="list-style-type: none"> NA
	e. Width of Corridor	<ul style="list-style-type: none"> NA 	<ul style="list-style-type: none"> NA 	<ul style="list-style-type: none"> NA
	f. Door Size	<ul style="list-style-type: none"> 1.0m 	<ul style="list-style-type: none"> 1.0m double door 	<ul style="list-style-type: none"> MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> 30 a/c per hour 12 a/c per hour 	<ul style="list-style-type: none"> NA Natural ventilated 	<ul style="list-style-type: none"> NA MR
5.	Fire Extinguishers			

N/17


	<ul style="list-style-type: none"> Total numbers Types IS marking 	08nos.	10nos.	MR
		ABC/CO2	ABC-10	MR
		ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Start/stop of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA


N/18


14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA	NA	NA
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA



Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education, and removal of shortcomings issued vide letter no. 39 dated 25.01.2021, the FSC issued vide letter no. F.6/DFS/MS/2017/School/WZ/491 dated 31.03.2017, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.


 Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO(Rohini)

DO (NW)

 11/04/2022
 By CFO (W3)


 20/4/2022

Ady Rohini S/o F-7 is put up for your perusal & signature
 Ms.

 21/4/2022
 MST cell

 21/4/2022