

e-10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI


No: F.6/DFS/MS/SCHOOL/2022/ 434

Dated: 21/04/2022

FIRE SAFETY CERTIFICATE

Certified that the building of **J.S. Public School**, located at **1st Floor, Shri sanatan Dharam Mandir (Puri Mandir), B-Block New Moti Nagar, New Delhi – 110015** in a building comprised of Ground plus one Upper floor, owned/occupied by **J.S. Public School**, was issued FSC vide Letter No:- F6/DFS/MS/School/2018/1880 Dated 09/08/2018. The premises was re-inspected by the officer concerned of this department on 04/04/2022 in the presence of M/s. Renu Sahajpal (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and that the premises is fit for occupancy class "Educational" Group/B with effect from 21/04/2022 for a period of three years subject to compliance of the conditions mentioned below.

Issued on 21/04/2022 at New Delhi by.


(Dharampal Bhardwaj)
Dy.Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Owner/Occupier J.S. Public School, 1st Floor, Shri Sanatan Dharam Mandir (Puri Mandir), B-Block New Moti Nagar, New Delhi – 110015 .
2. Director of Education, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good Working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The auditorium shall not be used for nay purpose till clearance is received from this department.

INSPECTION REPORT

1. Name & address of the building : J.S. Public School located 1st Floor, Shri Sanatan Dharam Mandir, (Puri Mandir) B-Block, New Moti Nagar New Delhi-110015.
2. Type of Occupancy : Educational (Ground Floor + One Upper Floor)(School is running at 1st floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/1880 dated 09/08/2018
5. Fire Safety directives letter No : 3298-3398 dated 01/03/2011
6. Date of inspection : 04/04/2022
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side : Ms. Renu Sahajpal (Principal)
9. Year of Construction : 2009 (As per prev. insp. report dtd-20/07/2018)
10. Applicant's letter No. : Letter No. Nil dated -16/03/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement As per prev. insp. report dtd-20/07/2018	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	5 m Provided	MR
	• Gate width	Accessible	350 cms Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1 X 1.5m	1X 120cms, 1 X105cms,	MR being old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	1.5 m	1.6 m Provided	MR
	f. Width of Corridor	01 mtr	1 mts Provided(Including door frame)	MR being old case
	g. Door Size			
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	03 nos.	03 Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	NR	NR	NR
	• Length of hose reel hose	NR	NR	NR
	• Nozzle diameter	NR	NR	NR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA

Provision of Lifts.

17	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

In view of the substantial compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2018/1880 dated 09/08/2018 renewal under DOE Circular no. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Directorate of Education, Govt. OF NCT of Delhi, is recommended.

101/ADOMN
05/04/2022

~~DO (w2)~~

[Signature]
Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADOMN

D.O. (F.T.) 463
DATED 06/04/2022

[Signature]
06/04/2022
~~DFE (w2)~~
18/4/2022

~~ADOMN~~ Sin F.T is put up for your personal & signature please.

[Signature]
19/4/2022
~~DFE (w2)~~
20/4/2022

MS/ cell

NA
NA
NA
NA
NA
NA