

449
442

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001


No.F6/DFS/MS/School/NDZ/2022/ 452

Dated:- 25/04/2022

FIRE SAFETY CERTIFICATE

Certified that the **Rajkiya Sarvodaya Kanya/Bal Vidyalaya** located at **Kalyanpuri, Delhi** building comprised of **3 Blocks A, B & C - Ground + 01 upper floor each block** owned/occupied by Rajkiya Sarvodaya Kanya/Bal Vidyalaya. The premises was re-inspected by the officers concerned of this department on 12/04/2022 in the presence of the Mr. Rajbir Bhandari (Estate Officer) and found that the said school have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class **"B" 'Educational Building'** with effect from for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 25/4/2022 at New Delhi by


(Anil Garg)
Director

Delhi Fire Service
etc

Copy to:-

1. The Director of Education,
EDMC, Udyog Sadan,
Plot No. 419, FIE, Patparganj, Delhi-92.
2. The Principal,
Rajkiya Sarvodaya Kanya/Bal Vidyalaya,
Kalyanpuri, Delhi-91. (School Id- 1002022, 1002008 & 10021212)

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building Rajkiya Sarvodaya Kanya/Bal Vidyalaya at Kalyanpuri, Delhi
2. Type of occupancy:- Educational Group-B
3 Block A, B & C - Gr. + 01 Upper floor each
3. Type of case:- New Case
4. Details of previous FSC:- N/A
5. Fire safety directives No.- F.16/Estate/CC/FireSafety/2011/3298to3398 dated 01/03/2011
6. Date of inspection:- 12/04/2022
7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer
From the building side:- Mr. Rajbir Bhandari (Estate Officer)
9. Year of construction:- 1977
10. Applicant's letter No:- email dated 12.04.22

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement As per circular	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	30 mtr.	MR
	2) Gate width	4.5 mtr.	4.5 mtr.	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 nos. each blk	05 nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 m or less	A-Block- 02 nos. 1.5 m B-Block- 01 nos. 1.5 m & 01 nos. 1.45 m C-Block- 01 nos. 1.37 m	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	03 nos.	03 nos.	MR
	E. Width of corridor	1.5 mtr. or less	1.2 mtr.	MR
	F. Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	013 Nos.	17 Nos.	MR

	1) Total numbers	013 Nos.	17 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A

M

N/17

02	MR
d	MR
	MR
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A
	N/A

	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. Both old block serving staircase with single staircase have been connected now (**photo enclosed**).

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer

Mush
T94

Name :- M.K. Sharma
Designation :- ADO (LN)

~~DO/ED~~ pl. speak.
AD
13/04/2022

~~ADO (LN)~~

Now both old blocks are connected pl

Mush
13/4



~~DO (LN)~~
AD
13/4/2022

Dy. CFO (NSZ) *CRP*
18/4/22

~~CFO (NSZ)~~

AD
19/4
AD
LN