

456
5599

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/BNQT/2022/W2/23

Dated: 26/4/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Atlantis Park Ballroom LLP Banquet Hall located at B-21, GF, FF, SF, G.T. Karnal Road Industrial Area, Delhi-110033 comprised of Ground, Mezzanine-I, First Floor, Mezzanine-II & Second Floors Only owned/ occupied by M/s Atlantis Park Ballroom LLP Banquet was issued fire safety certificate vide letter no. F6/DFS/MS/2019/WZ/1464 dated 17.07.2019. The premises was re-inspected by the officer concerned of Fire Service on 13.04.2022 in the presence of Sh. Ranjan Puri and observed that all the fire prevention and fire safety arrangements as provided in the premise found good working condition. The premise have therefore deemed complied with the fire prevention and fire safety measures in accordance with the rule 33 of Delhi Fire Service Rules, 2010 and that the building / premise is fit for occupancy class "Assembly Group D-3 (Banquet Hall)" with effect from 26/4/2022 for a period of three years in accordance with rules 36 unless renewed under rule. 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/4/2022 at New Delhi by

26/4/2022
(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph: 01125156707
ofc

Copy to :-

1. The Dy. Commissioner, (Civil Line Zone) North Delhi Municipal Corporation, 16, Rajpura Road, New Delhi-110054.
2. The Joint Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi-110049.
3. The Manager, M/s Atlantis Park Ballroom LLP Banquet Hall located at B-21, GF,FF,SF, G.T. Karnal Road Industrial Area, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : Atlantis Park Ballroom LLP Banquet Hall at B-21, GF & FF & SF, G,T,K Road, Industrial Area, Delhi-110033.
2. Composition of building : Ground floor + Mezzanine-I+ First floor + Mezzanine-II & Second Floor only)
3. Type of Occupancy : Assembly
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2019/WZ/1464 Dated:17.07.2019
6. Fire Safety directives letter No : F.6/DFS/MS/2019/168 dated : 02.05.2019
7. Date of inspection : 13.04.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Mr. Ranjan Puri
10. Year of Construction : 2018
11. Applicant's letter No. : Online Portal I.D No.2022032604232 dated 28.03.2022

Total plot area—885.50sqm.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	18m (approx)	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02	02	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases	2 m each & Mezz-II-2m & 1.50m	2m each & Mezz-II-2m & 1.50m	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	c. Protection of exits	Required	Provided	MR
	• Fire check door	NA	NA	NA
	• Pressurization	01	01	MR
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	2.0m x02	Provided	MR
f. Door Size				
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	15nos	16 nos	MR
	<ul style="list-style-type: none"> Types 	ABC & Co2	16- ABC	MR
	<ul style="list-style-type: none"> ISI marking 	Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	02	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	01	MR
	<ul style="list-style-type: none"> Hose Box 	01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	Required.01	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Required.01	Provided	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	2280lpm	2280lpm	MR
	<ul style="list-style-type: none"> ➤ Head of Main pump 	70m	70m	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	180lpm	180lpm	MR
	<ul style="list-style-type: none"> ➤ Jockey pump head 	70m	70m	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	2280 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	70m	70m	MR
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Pump House Access 			
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	40m	Provided	MR
	<ul style="list-style-type: none"> ➤ Power Supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	Required	Provided	MR
14	Captive Water Storage for fire fighting.			

	<ul style="list-style-type: none"> Underground tank capacity 	1,00,000ltr.	Provided	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> Overhead Tank capacity 	5,000ltr	5,000ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	Required	Provided	MR
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	Required	Provided	MR
	<ul style="list-style-type: none"> Communication In lift Car 	NA	40m	NA
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> Lift Signage 	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Location 	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Batter backup 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. 1464 dated 17.07.2019 under rule 37 of the Delhi Fire Service Rules 2010.

DO (N/W)

[Signature]
18/04/2022

By CPO (W2)

Put up as per your office order ~~and~~ recently issued please.

[Signature]

Signature of the Inspecting Officer
Name: - C.L. Meena
Designation:- ADO/RN

[Signature]
18/4/2022
ADO/RN

CPO. Not available
Inspector *[Signature]*
19/04/2022

PLS
SPK