

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No. F6/DFS/MS/2022/ School/ NDZ/457

Dated: 26/4/2022

FIRE SAFETY CERTIFICATE

Certified that the **CONVENT OF JESUS AND MARY**, located at 01 Bangla Sahib Road, New Delhi. The school complex is comprised of Sr. Secondary Block (Ground + 01 upper floor), Middle block (Basement + Gr+ 02 upper floor) and auditorium block (Basement + Gr. + 03 upper floor). The premises was inspected by the officers concerned of this department on 24-03-2022 in the presence of Ms. Arti and found that the **Sr. Secondary Block (Ground + 01 upper floor)**, has complied with the fire prevention and fire safety requirements in accordance with **Director of education circular no. F16/Estate/CC/Fire safety 2011/3298-3398 dated 01.03.2011** and that the premises is fit for occupancy of class Group B "**Educational Building**" **Sr. Secondary Block (Ground + 01 upper floor) only** with effect from 26/4/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on 26/4/2022 at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service
u

Copy to:-

1. Director of Education, Govt. of NCT, Old Secretariat, Delhi.
2. The Principal, CONVENT OF JESUS AND MARY, 01 Bangla Sahib Road, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
2. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
8. The FSC is valid for school Sr. Secondary Block only.

INSPECTION REPORT

1.	Name & address of the building	Covent of Jesus and Merry school situated 01 Bangla Sahib Road , New Delhi
2.	Type of occupancy:-	Educational group -B Middle school Block – Basement(library) Ground + 02 upper floor
3	Type of case:-	New case
4	Details of previous FSC:-	N/A
5	Fire safety directives No.-	Director of education circular no F16/Estate/CC/Fire safety 2011/3298-3398 dated 01.03.2011
6	Date of inspection:-	24.03.2022
7	Name of the inspecting officer:-	Sh. Ravinder singh (ADO/CC) Sh. Rajinder Atwal , DO (CD)
8	Name & designation of officer From the building side:-	<u>Ms Arti</u>
9	Year of construction:-	N/A
10	Applicant's letter No:-	Dated 15.03.2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06mtr	06 mtr.	MR
	2) Gate width	05 mtr	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	Upper floors	05	05	MR
	Basements	02 Nos	01 nos	NMR
	B. Width of staircase			
	Upper floors	3x1.5m 1x1.0m&1x1.40m	3x1.5m 1x1.0m&1x1.40m	MR
	Basement	1.5m & .75	1x1.5m	NMR
	C. Protection of exits			
	1. Fire check door	Required in basement	Not provided	NMR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	03	03	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	01 mtr.	01 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A



N/32

	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	Mechanical	MR
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	20 Nos.	16 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number at each floor	02	02	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100mm	100mm	MR
	2) Number of hydrants per floor	02	02	MR
	3) Hose box	02	02	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	6) Ground level	N/A	N/A	N/A
	g) Discharge of main pump	N/A	N/A	N/A
	r) Head of main pump	N/A	N/A	N/A
	s) Number of main pump	N/A	N/A	N/A
	t) Jockey pump out put	N/A	N/A	N/A
	u) Jockey pump head	N/A	N/A	N/A
	v) Stand by pump output	N/A	N/A	N/A
	w) Stand by pump head	N/A	N/A	N/A
	x) Auto starting/Manual stopping	N/A	N/A	N/A
	7) Terrace level			
	i) Discharge of pump	450 LPM	450 LPM	MR
	j) Head of pump	30 mtr.	30 mtr.	MR
	k) Power supply	Required	Provided	MR
	l) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	3) Under ground tank capacity	N/A	N/A	N/A
	i) Draw-off connection	N/A	N/A	N/A
	j) Fire service inlet	N/A	N/A	N/A



2133

N/A
N/A
N/A
N/A

MR
MR

MR
MR
MR

MR
MR
MR

A
A
A

	k) Access to tank	Required	Provided	MR
	l) Over head tank capacity	15,000 ltr.	15,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	k) Pressurization of lift shaft	N/A	N/A	N/A
	l) Pressurization of lift lobby	N/A	N/A	N/A
	m) Communication in lift car	N/A	N/A	N/A
	n) Fireman's switch	N/A	N/A	N/A
	o) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	k) Detector system panel	N/A	N/A	N/A
	l) Flow switch panel	N/A	N/A	N/A
	m) PA system panel	N/A	N/A	N/A
	n) Battery backup	N/A	N/A	N/A
	o) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & CO²			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the non-compliance of the minimum standards on fire Prevention and fire safety required under the rules, if agreed, we may issue shortcomings as mentioned at sl no. 2.

Signature of the Inspecting Officer

[Signature]
01/4/22

Name :- Rajinder Atwal
Designation :- DO (CD)

Signature of the Inspecting Officer

[Signature]
31/3/22

Name :- Ravinder Singh
Designation :- ADO (CC)

[Signature]
Dy. Commr

[Signature]
11/4/22

[Signature]
CFO (CD)

[Signature]
4/4

[Signature]
3/04/22

[Signature]
DO (CD)

